

**NORME
INTERNATIONALE
INTERNATIONAL
STANDARD**

**CEI
IEC**

61326-2-5

Première édition
First edition
2006-06

**Matériel électrique de mesure, de commande
et de laboratoire – Exigences relatives à la CEM –**

**Partie 2-5:
Exigences particulières – Configurations d'essai,
conditions de fonctionnement et critères
d'aptitude à la fonction pour les dispositifs en
exploitation avec des interfaces conformes
à la CEI 61784-1, CP 3/2**

**Electrical equipment for measurement, control
and laboratory use – EMC requirements –**

**Part 2-5:
Particular requirements – Test configurations,
operational conditions and performance criteria
for field devices with interfaces according to
IEC 61784-1, CP 3/2**

© IEC 2006 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

J

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

MATÉRIEL ÉLECTRIQUE DE MESURE, DE COMMANDE ET DE LABORATOIRE – EXIGENCES RELATIVES À LA CEM –

Partie 2-5: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les dispositifs en exploitation avec des interfaces conformes à la CEI 61784-1, CP 3/2

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI n'a prévu aucune procédure de marquage valant indication d'approbation et n'engage pas sa responsabilité pour les équipements déclarés conformes à une de ses Publications.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

La Norme internationale CEI 61326-2-5 a été préparée par le sous-comité 65A: Aspects systèmes, du comité d'études 65 de la CEI: Mesure et commande dans les processus industriels.

La série CEI 61326 annule et remplace la CEI 61326:2002 et constitue une révision technique.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE – EMC REQUIREMENTS –

Part 2-5: Particular requirements – Test configurations, operational conditions and performance criteria for field devices with interfaces according to IEC 61784-1, CP 3/2

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61326-2-5 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement and control.

The IEC 61326 series cancels and replaces IEC 61326:2002 and constitutes a technical revision.

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
65A/474/FDIS	65A/479/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Cette partie de la CEI 61326 doit être utilisée en conjonction avec la CEI 61326-1 et elle suit le même système de numérotation des articles, paragraphes, tableaux et figures que cette dernière.

La CEI 61326 est constituée des parties suivantes, sous le titre général *Matériel électrique de mesure, de commande et de laboratoire – Exigences relatives à la CEM*:

- Partie 1: Exigences générales
- Partie 2-1: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les matériels d'essai et de mesure sensibles destinés aux application non protégées contre la CEM
- Partie 2-2: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction des matériels portatifs d'essai, de mesure et de surveillance utilisés dans des systèmes de distribution basse tension
- Partie 2-3: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les transducteurs avec conditionnement de signal intégré ou à distance
- Partie 2-4: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les dispositifs de surveillance d'isolation en accord avec la CEI 61557-8 et pour les équipements de localisation de défaut d'isolation en accord avec la CEI 61557-9
- Partie 2-5: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les dispositifs en exploitation avec des interfaces conformes à la CEI 61784-1, CP 3/2
- Partie 2-6: Exigences particulières – Matériel médical de diagnostic *in vitro* (IVD)
- Partie 3-1: Exigences d'immunité pour les matériels effectuant ou prévus pour exécuter des fonctions en relation avec la sécurité (sécurité fonctionnelle) – Applications industrielles générales

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de maintenance indiquée sur le site web de la CEI sous «<http://webstore.iec.ch>» dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite;
- supprimée;
- remplacée par une édition révisée, ou
- amendée.

The text of this standard is based on the following documents:

FDIS	Report on voting
65A/474/FDIS	645A/479/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part of IEC 61326 is to be used in conjunction with IEC 61326-1 and follows the same numbering of clauses, subclauses, tables and figures as that standard.

IEC 61326 consists of the following parts, under the general title *Electrical equipment for measurement, control and laboratory use – EMC requirements*:

- Part 1: General requirements
- Part 2-1: Particular requirements – Test configurations, operational conditions and performance criteria for sensitive test and measurement equipment for EMC unprotected applications
- Part 2-2: Particular requirements – Test configurations, operational conditions and performance criteria for portable test, measuring and monitoring equipment used in low-voltage distribution systems
- Part 2-3: Particular requirements – Test configuration, operational conditions and performance criteria for transducers with integrated or remote signal conditioning
- Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9
- Part 2-5: Particular requirements – Test configurations, operational conditions and performance criteria for field devices with interfaces according to IEC 61784-1, CP 3/2
- Part 2-6: Particular requirements – *In vitro* diagnostic (IVD) medical equipment
- Part 3-1: Immunity requirements for equipment performing or intended to perform safety-related functions (functional safety) – General industrial applications

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

MATÉRIEL ÉLECTRIQUE DE MESURE, DE COMMANDE ET DE LABORATOIRE – EXIGENCES RELATIVES À LA CEM –

Partie 2-5: Exigences particulières – Configurations d'essai, conditions de fonctionnement et critères d'aptitude à la fonction pour les dispositifs en exploitation avec des interfaces conformes à la CEI 61784-1, CP 3/2

1 Domaine d'application

En complément aux exigences de la CEI 61326-1, la présente partie de la CEI 61326 traite les aspects particuliers des essais CEM pour les dispositifs ayant des interfaces conformes à la CEI 61784-1, CP 3/2. Cette partie de la CEI 61326 couvre uniquement les interfaces des bus de terrain de l'équipement.

NOTE Les autres fonctions de l'équipement sont couvertes par d'autres parties de la série CEI 61326.

La présente partie de la CEI 61326 couvre uniquement les dispositifs de terrain destinés aux processus de commande et aux processus de mesure.

Pour le fonctionnement des interfaces et les paramètres de ces derniers, cette partie de la CEI 61326 est conforme à la CEI 61784-1, CP 3/2. Cette dernière spécifie un jeu de protocoles spécifiques de profils de communication basés sur la CEI 61158.

Le fabricant spécifie l'environnement auquel le produit est destiné et utilise les spécifications du niveau d'essai pertinentes de la série CEI 61326-1.

2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

L'Article 2 de la CEI 61326-1 est applicable à l'exception de ce qui suit:

Addition:

CEI 61326-1:2005, *Matériel électrique de mesure, de commande et de laboratoire – Exigences relatives à la CEM – Partie 1: Exigences générales*

CEI 61158 (toutes les parties): *Digital data communications for measurement and control – Field-bus for use in industrial control systems* (disponible en anglais seulement)

CEI 61158-2: *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 2: Physical layer specification and service definition* (disponible en anglais seulement)

CEI 61158-3, *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 3: Data link service definition* (disponible en anglais seulement)

**ELECTRICAL EQUIPMENT FOR MEASUREMENT,
CONTROL AND LABORATORY USE –
EMC REQUIREMENTS –**

**Part 2-5: Particular requirements – Test configurations,
operational conditions and performance criteria for field devices
with interfaces according to IEC 61784-1, CP 3/2**

1 Scope

In addition to the requirements of IEC 61326-1, this part of IEC 61326 treats the particular features for EMC testing of field devices with interfaces according to IEC 61784-1, CP 3/2. This part of IEC 61326 covers only the field-bus interface of the equipment.

NOTE The other functions of the equipment are covered by other parts of the IEC 61326 series.

This part of IEC 61326 refers only to field devices intended for use in process control and process measuring.

For interface operation and the interface parameters, this part of IEC 61326 is in accordance with IEC 61784-1, CP 3/2. That standard specifies a set of protocol specific communication profiles based on the IEC 61158 series.

The manufacturer specifies the environment for which the product is intended to be used and/or selects the appropriate test level specifications of IEC 61326-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Clause 2 of IEC 61326-1 applies, except as follows:

Addition:

IEC 61326-1:2005, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61158 (all parts), *Digital data communications for measurement and control – Field-bus for use in industrial control systems*

IEC 61158-2, *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 2 :Physical layer specification and service definition*

IEC 61158-3, *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 3 :Data link service definition*

CEI 61158-5: *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 5 : Application layer service definition* (disponible en anglais seulement)

CEI 61158-6: *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 6 : Application layer protocol specification* (disponible en anglais seulement)

CEI 61784 (toutes les parties¹), *Digital data communications for measurement and control* (disponible en anglais seulement)

CEI 61784-1, *Digital data communications for measurement and control – Part 1 : Profile sets for continuous and discrete manufacturing relative to fieldbus use in industrial control systems* (disponible en anglais seulement)

¹ D'autres parties sont à l'étude.

IEC 61158-5, *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 5 : Application layer service definition*

IEC 61158-6, *Digital data communications for measurement and control – Field-bus for use in industrial control systems – Part 6 : Application layer protocol specification*

IEC 61784 (all parts¹), *Digital data communications for measurement and control*

IEC 61784-1, *Digital data communications for measurement and control – Part 1 : Profile sets for continuous and discrete manufacturing relative to fieldbus use in industrial control systems*

¹ Other parts are under consideration.