

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Programmable controllers –
Part 2: Equipment requirements and tests**

**Automates programmables –
Partie 2: Exigences et essais des équipements**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 61131-2

Edition 3.0 2007-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Programmable controllers –
Part 2: Equipment requirements and tests**

**Automates programmables –
Partie 2: Exigences et essais des équipements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XF

ICS 25.040.40; 35.240.50

ISBN 978-2-88912-076-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
INTRODUCTION.....	12
1 General.....	14
1.1 Scope and object.....	14
1.2 Compliance with this standard.....	15
1.3 Normative references.....	15
2 Type tests.....	18
2.1 Equipment to be tested (equipment under test/EUT).....	18
2.2 Special features for immunity and EMC tests.....	20
2.3 Withstand test conditions.....	21
2.4 Verification procedure.....	21
2.5 Requirements for test programmes and proper functioning verification procedures (PFVPs) to be provided by the manufacturer.....	21
2.6 General conditions for tests.....	22
3 Terms and definitions.....	22
4 Normal service conditions and requirements.....	29
4.1 Climatic conditions and requirements.....	30
4.1.1 Operating ambient air temperature.....	30
4.1.2 Relative humidity.....	30
4.1.3 Altitude.....	30
4.1.4 Pollution degree.....	30
4.2 Mechanical service conditions and requirements.....	30
4.2.1 Vibrations.....	31
4.2.2 Shock.....	31
4.2.3 Free falls (portable and hand-held equipment).....	31
4.3 Transport and storage conditions and requirements.....	32
4.3.1 Temperature.....	32
4.3.2 Relative humidity.....	32
4.3.3 Altitude.....	32
4.3.4 Free falls (PLC units in manufacturer's original packaging).....	32
4.3.5 Other conditions.....	33
4.4 Electrical service conditions and requirements.....	33
4.4.1 AC and d.c. equipment power supply.....	33
4.4.2 Overvoltage category, control of transient overvoltages.....	33
4.4.3 Non-periodic overvoltages.....	33
4.5 Special conditions and requirements.....	33
5 Functional requirements.....	33
5.1 Functional power supply and memory back-up requirements.....	35
5.1.1 AC and d.c. power supply.....	35
5.1.2 Memory back-up.....	36
5.2 Digital I/Os.....	37
5.2.1 Digital inputs (current sinking).....	38
5.2.2 Digital outputs for alternating currents (current sourcing).....	39
5.2.3 Digital outputs for direct current (current sourcing).....	42

5.3	Analogue I/Os	43
5.3.1	Analogue inputs.....	43
5.3.2	Analogue outputs.....	44
5.4	Communication interface requirements.....	44
5.5	Main processing unit(s) and memory(ies) of the PLC-system requirements	44
5.6	Remote input/output stations (RIOSs) requirements	44
5.7	Peripherals (PADTs, TEs, HMIs) requirements	45
5.8	PLC-system self-tests and diagnostics requirements	45
5.9	Functional earthing.....	46
5.10	Mounting requirements	46
5.11	General marking requirements	46
5.11.1	Functional identifications	46
5.11.2	Module location and module identifications.....	46
5.11.3	Functional earth terminals markings	46
5.12	Requirements for normal service and functional type tests and verifications	47
5.13	Requirements for information on normal service and function	47
6	Normal service and functional type tests and verifications	47
6.1	Climatic tests	47
6.2	Dry-heat and cold withstand tests.....	47
6.2.1	Variation of temperature	48
6.2.2	Cyclic damp heat withstand test	49
6.3	Mechanical tests	50
6.3.1	Vibration (type test associated with normal service conditions).....	50
6.3.2	Shock (type test associated with normal service conditions)	50
6.3.3	Free fall (type test associated with normal service conditions).....	51
6.3.4	Free fall (type test associated with transport and storage conditions)	51
6.3.5	Plugging/unplugging of removable units.....	51
6.4	Verification of special functional requirements for power ports and memory back-up – Special immunity limits for power ports	51
6.4.1	Verification of functional equipment power input port (a.c. or d.c.)	52
6.4.2	External energy supply variation tests (immunity tests).....	53
6.4.3	Improper equipment power supply connection tests	56
6.4.4	Verification of memory back-up requirements	57
6.5	Verification of input/output requirements	57
6.5.1	General	57
6.5.2	Verification of digital inputs.....	58
6.5.3	Verification of digital outputs	58
6.5.4	Verification of analogue I/Os.....	59
6.6	Verification of communication interface requirements	60
6.7	Verification of MPU requirements	60
6.8	Verification of remote I/O stations	61
6.8.1	Response time test.....	61
6.8.2	Loss of communication test	61
6.8.3	Verification of other requirements	61
6.9	Verification of peripheral (PADTs, TEs, HMIs) requirements.....	61
6.10	Verification of PLC-system self-tests and diagnostics	61
6.11	Verification of markings and manufacturer's documentation.....	61
7	General information to be provided by the manufacturer.....	62
7.1	Information on type and content of documentation.....	62

7.1.1	Information on catalogues and datasheets.....	62
7.1.2	Information on user's manuals	62
7.1.3	Information on technical documentation.....	62
7.2	Information on compliance with this standard	62
7.3	Information on reliability	63
7.4	Information on other conditions	63
7.5	Information on shipping and storage.....	63
7.6	Information on a.c. and d.c. power supply	63
7.7	Information on digital inputs (current sinking)	63
7.8	Information on digital outputs for alternating currents (current sourcing).....	64
7.9	Information on digital outputs for direct current (current sourcing)	65
7.10	Information on analogue inputs	65
7.10.1	Information on analogue input static characteristics.....	65
7.10.2	Information on analogue input dynamic characteristics	65
7.10.3	Information on analogue input general characteristics	66
7.10.4	Information on analogue input miscellaneous characteristics	66
7.11	Information on analogue outputs	66
7.11.1	Information on analogue output static characteristics.....	66
7.11.2	Information on analogue output dynamic characteristics	66
7.11.3	Information on analogue output general characteristics	67
7.11.4	Information on analogue output miscellaneous characteristics	67
7.12	Information on communication interfaces.....	67
7.13	Information on main processing unit(s) and memory(ies) of the PLC-system	67
7.14	Information on remote input/output stations (RIOs)	68
7.15	Information on peripherals (PADTs, TEs, HMIs)	69
7.16	Information on self-tests and diagnostics.....	69
8	Electromagnetic compatibility (EMC) requirements	69
8.1	General.....	69
8.2	Emission requirements	70
8.2.1	General requirements for emission	70
8.2.2	Emission limits in the low-frequency range	70
8.2.3	Emission limits in the high-frequency range	70
8.3	EMC immunity requirements.....	70
8.3.1	General	71
8.3.2	Performance criteria	72
8.3.3	Immunity levels.....	73
8.3.4	Voltage dips and interruptions power ports	75
8.4	Requirements for EMC tests and verifications	76
8.5	Requirements for information on EMC	76
9	Electromagnetic compatibility (EMC) type tests and verifications	76
9.1	Electromagnetic compatibility-related tests.....	76
9.2	Test environment.....	77
9.3	Measurement of radiated interference	77
9.4	Measurement of conducted interference.....	77
9.5	Electrostatic discharge	78
9.6	Radiofrequency electromagnetic field – Amplitude modulated	78
9.7	Power-frequency magnetic fields	79
9.8	Fast transient bursts.....	79

9.9	High-energy surges	80
9.10	Conducted radiofrequency interference	80
9.11	Damped oscillatory wave (for zone C only)	81
9.12	Voltage dips and interruptions	81
10	Electromagnetic compatibility (EMC) information to be provided by the manufacturer	82
11	Safety requirements	82
11.1	Equipment types and protection	82
11.1.1	Open PLC-system equipment	82
11.1.2	Enclosed PLC-system equipment	82
11.2	Protection against electrical shock	84
11.2.1	Permissible limits for accessible parts	84
11.2.2	Dielectric strength	85
11.2.3	Ports requiring protection	86
11.2.4	Protection in normal condition	86
11.2.5	Protection in single-fault condition	87
11.2.6	Secondary circuits which do not pose a risk of electrical shock.....	88
11.3	Protection against the spread of fire	89
11.3.1	Limited power circuits	89
11.4	Clearance and creepage distances requirements	90
11.4.1	Clearances relating to overvoltage category II	91
11.4.2	Clearances for micro-environment where voltages are known and controlled	93
11.4.3	Creepage distances for basic and supplementary insulation	93
11.4.4	Creepage distances for double/reinforced insulation	96
11.4.5	Creepage for field-wiring terminals	96
11.5	Flame-retardant requirements for non-metallic materials	96
11.5.1	Non-metallic enclosure material	96
11.5.2	Non-metallic material supporting live parts	96
11.5.3	Non-metallic parts	97
11.5.4	Decorative and labelling materials	97
11.5.5	Internal wiring or interconnection cables	97
11.6	Temperature limits	97
11.7	Enclosures	97
11.7.1	Open equipment	98
11.7.2	Enclosed equipment	98
11.8	Operator-accessible hazardous live field-wiring terminal constructional requirements	98
11.9	Provisions for protective earthing	98
11.9.1	Protective earthing requirements for enclosed equipment	99
11.9.2	Protective earthing requirements for open equipment	99
11.10	Wiring	100
11.10.1	Internal wiring	100
11.10.2	Interconnection wiring	100
11.10.3	Equipment power input cord	100
11.11	Switching devices	101
11.12	Components related to safety requirements	101
11.13	Battery requirements	101
11.14	Maximum voltage and minimum voltage	101
11.15	Markings and identification	101

11.15.1	External wiring terminals identification	102
11.15.2	Live parts	102
11.15.3	Protective earth terminals markings.....	102
11.15.4	Enclosed Class II equipment	102
11.15.5	Equipment supplied by SELV/PELV.....	103
11.15.6	Rating information	103
11.16	Requirements for safety type tests and verifications	103
11.17	Requirements for safety routine tests and verifications	103
11.17.1	Requirement for dielectric strength verification.....	103
11.17.2	Requirement for protective earthing verification.....	103
11.18	Requirements for information on safety.....	103
12	Safety type tests and verifications	104
12.1	Safety-related mechanical tests and verifications	104
12.1.1	Impact withstand test.....	104
12.1.2	Operator accessibility tests.....	105
12.1.3	General examination of openings.....	105
12.1.4	Wire flexing test.....	106
12.1.5	Temperature test	106
12.1.6	Protective coating test	106
12.1.7	Rigidity test	106
12.1.8	Clearance and creepage verification.....	107
12.1.9	Field-wiring terminals constructional verification	107
12.2	Safety-related electrical tests	107
12.2.1	Dielectric withstand verification test.....	107
12.2.2	Protective earthing continuity test.....	109
12.2.3	Stored energy injury risk test	110
12.2.4	Overload test.....	110
12.2.5	Endurance test	110
12.3	Single-fault condition tests	111
12.3.1	Single-fault condition – General.....	111
12.3.2	Single-fault condition – Breakdown of components test	111
12.3.3	Single-fault condition – Protective impedance test.....	112
12.3.4	Single-fault condition – isolation transformers test.....	112
12.4	Limited power circuits test	112
13	Safety routine tests	112
13.1	Dielectric withstand test	112
13.2	Dielectric withstand verification test.....	113
13.3	Protective earthing test	113
14	Safety information to be provided by the manufacturer	113
14.1	Information on evaluation of enclosures for open equipment (power dissipation).....	114
14.2	Information on mechanical terminal connection	114
Annex A (informative) Illustration of PLC-system hardware definitions		115
Annex B (informative) Digital input standard operating range equations.....		116
Annex C (normative) Test tools.....		117
Annex D (informative) Zone C – EMC immunity levels		120
Annex E (informative) Overvoltage example.....		122

Bibliography.....	124
Figure 1 – EUT configurations	20
Figure 2 – Typical interface/port diagram of a PLC-system	34
Figure 3 – I/O Parameters.....	37
Figure 4 – U-I operation regions of current-sinking inputs	38
Figure 5 – Temporary overload waveform for digital a.c. outputs.....	40
Figure 6 – Temporary overload waveform for digital d.c. outputs.....	43
Figure 7 – Third harmonic immunity test	53
Figure 8 – Gradual shut-down/start-up test	54
Figure 9 – Fast supply voltage variation test	55
Figure 10 – Slow supply voltage variation test	56
Figure 11 – EMC immunity zones.....	71
Figure 12 – Impact withstand test procedure.....	104
Figure 13 – Dielectric withstand test procedures	109
Figure A.1 – Programmable controller system (PLC-system).....	115
Figure C.1 – Jointed test finger.....	117
Figure C.2 – 15 mm × 3 mm test pin	118
Figure C.3 – 100 mm × 4 mm test pin	118
Figure C.4 – 100 mm × 3 mm test pin	119
Figure E.1 – Creepage distances of circuits where recurring peak voltages are generated	122
Table 1 – General conditions for tests.....	22
Table 2 – Operating ambient air temperature of PLC-systems.....	30
Table 3 – Sinusoidal vibrations service conditions for PLC-systems.....	31
Table 4 – Free fall on concrete floor for portable and hand-held equipment	31
Table 5 – Free fall on concrete floor in manufacturer's original packaging	33
Table 6 – Rated values and operating ranges of incoming power supply.....	35
Table 7– Voltage interruptions (functional requirements).....	36
Table 8 – Standard operating ranges for digital inputs (current sinking)	39
Table 9 – Rated values and operating ranges for current sourcing digital a.c. outputs	40
Table 10 – Rated values and operating ranges (d.c.) for current-sourcing digital d.c. outputs	42
Table 11 – Rated values and impedance limits for analogue inputs.....	43
Table 12 – Rated values and impedance limits for analogue outputs.....	44
Table 13 – Dry-heat and cold withstand tests.....	47
Table 14 – Change of temperature, withstand and immunity tests	48
Table 15 – Cyclic (12 + 12) damp-heat test.....	49
Table 16 – Immunity vibration test	50
Table 17 – Immunity shock test.....	50
Table 18 – Free-fall immunity/withstand tests (portable and hand-held equipment)	51
Table 19 – Free-fall withstand test (units within manufacturer's original packaging)	51

Table 20 – Insertion/withdrawal of removable units	51
Table 21 – Voltage ripple and frequency range immunity test.....	52
Table 22 – Third harmonic immunity test.....	52
Table 23 – Gradual shut-down/start-up test	54
Table 24 – Supply voltage variation tests.....	55
Table 25 – Voltage interruptions immunity test (Functional tests).....	56
Table 26 – Back-up duration withstand test.....	57
Table 27 – Change of energy source test.....	57
Table 28 – Overload and short-circuit tests for digital outputs	59
Table 29 – Emission limits	70
Table 30 – EMC immunity zones, example regarding surge	72
Table 31 – Criteria to prove the performance of a PLC-system against EMC disturbances	72
Table 32 – Enclosure port tests, Zones A and B.....	73
Table 33 – Conducted immunity tests, Zone B	74
Table 34 – Conducted immunity tests, zone A.....	75
Table 35 – Voltage dips and interruptions (EMC requirements)	76
Table 36 – Radiated emission measurement.....	77
Table 37 – Conducted emission measurement	77
Table 38 – Electrostatic discharge immunity test.....	78
Table 39 – Radiated electromagnetic field immunity test.....	78
Table 40 – Power-frequency magnetic field immunity test	79
Table 41 – Fast transient burst immunity test	79
Table 42 – High-energy surge immunity test	80
Table 43 – Conducted r.f. immunity test.....	80
Table 44 – Damped oscillatory wave immunity test	81
Table 45 – Voltage dips and interruptions immunity test (EMC tests)	81
Table 46 – Shock protection requirements for open and enclosed equipment.....	86
Table 47 – Limits of output current and output power for inherently limited power sources.....	90
Table 48 – Limits of output current, output power and ratings for over-current protective devices for non-inherently limited power sources.....	90
Table 49 – Minimum clearances in air corresponding to overvoltage category II conditions (except for field wiring terminals) for basic/supplementary insulation.....	91
Table 50 – Minimum clearances in air corresponding to overvoltage category II conditions (except for field wiring terminals) for double /reinforced insulation	92
Table 51 – Minimum clearances in air at field-wiring terminals	92
Table 52 – Minimum clearances in air for micro-environment where the voltages are known and controlled	93
Table 53 – Classification of material group according to comparative tracking index (CTI).....	94
Table 54 – Minimum creepage distances for other than printed circuit boards (1).....	94
Table 55 – Minimum creepage distances for printed circuit boards (1), (6), (9) (basic and supplementary insulation)	95

Table 56 – Minimum creepage distances related to recurring peak voltages on printed wiring boards without protective coating (1) (pollution degrees 1 and 2).....	96
Table 57 – Temperature limits	97
Table 58 – Impact withstand test (1)	104
Table 59 – Operator accessibility tests (1)	105
Table 60 – Dielectric withstand voltages for impulse a.c. power-frequency and d.c. tests for basic/supplementary insulation (5)	108
Table 61 – Dielectric withstand voltages for impulse a.c. power frequency and d.c. tests for double/reinforced insulation (5)	109
Table 62 – Overload test circuit values	110
Table 63 – Endurance test circuit values.....	111
Table 64 – Routine dielectric withstand test (5).....	113
Table D.1 – Enclosure port tests, Zone C.....	120
Table D.2 – Conducted immunity tests, Zone C.....	121

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROGRAMMABLE CONTROLLERS –

Part 2: Equipment requirements and tests

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61131-2 has been prepared by subcommittee 65B: Measurement and control devices, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition of IEC 61131-2 cancels and replaces the second edition published in 2003 and constitutes a technical revision.

This third edition includes the following significant technical changes with respect to the previous edition.

- a) DC power port requirements have been moved from Clause 8 to Clause 5.
- b) Correction of the following tests of Clause 6:
 - voltage range test;
 - fast supply voltage variation test;
 - slow supply voltage variation test;
 - gradual shut-down/start-up test.

- c) Change of EMC requirements in Clause 8:
- requirements for radiofrequency interference in Table 33 changed from 3 V to 10 V for Zone B equipment;
 - reference to EMC basic standards with the last version;
 - reference to generic standards 61000-6-x;
 - cable length aligned to generic standards.
- d) Correction of the following tests in Clause 9:
- voltage dips and interruptions – power port type tests and verifications.
- e) New organization of Clause 11:
- equipment types and protection;
 - open PLC-system equipment;
 - enclosed PLC-system equipment:
 - Class I equipment;
 - Class II equipment;
 - Class III equipment;
 - protection against electric shock;
 - definition of secondary circuits which do not pose a risk of electric shock:
 - Class 2 circuit;
 - limited voltage/current circuit;
 - limited voltage circuit;
 - limited energy circuit ≤ 30 V a.c. or 42,2 V peak;
 - limited impedance circuit;
 - protection against the spread of fire within limited power circuits;
 - protective earthing requirements for enclosed equipment;
 - minor improvements in different subclauses;
 - impulse test only for verification of clearances.

This bilingual version (2012-05) corresponds to the monolingual English version, published in 2007-07.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/623/FDIS	65B/636/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of the IEC 61131 series, under the general title *Programmable controllers*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61131-2 is part of a series of standards on programmable controllers and the associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

Compliance with IEC 61131-2 cannot be claimed unless the requirements of 7.2 are met.

Service and physical environment requirements are specified in Clause 4. Functional requirements are specified in Clause 5. Electromagnetic compatibility requirements are specified in Clause 8. Safety requirements are specified in Clause 11.

Terms of general use are defined in IEC 61131-1. More specific terms are defined in each part.

PROGRAMMABLE CONTROLLERS –

Part 2: Equipment requirements and tests

1 General

1.1 Scope and object

This part of IEC 61131 specifies requirements and related tests for programmable controllers (PLCs) and their associated peripherals (for example, programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc.) which have as their intended use the control and command of machines and industrial processes.

PLCs and their associated peripherals are intended to be used in an industrial environment and may be provided as open or enclosed equipment. If a PLC or its associated peripherals are intended for use in other environments (light industrial, commercial, residential), then the specific requirements, standards and installation practices for those other environments should be additionally applied to the PLC and its associated peripherals.

This standard also applies to any products performing the function of PLCs and/or their associated peripherals.

Equipment covered in this standard is intended for use in overvoltage category II (IEC 60664-1) in low-voltage installations, where the rated equipment supply voltage does not exceed a.c. 1 000 V r.m.s. (50/60 Hz), or d.c. 1 500 V. (If PLCs or their associated peripherals are applied in overvoltage category III installations, then additional analysis will be required to determine the suitability of the equipment for those applications.)

This standard does not deal with the functional safety or other aspects of the overall automated system. PLCs, their application programme and their associated peripherals are considered as components of a control system.

Since PLCs are component devices, safety considerations for the overall automated system including installation and application are beyond the scope of this standard. Refer to IEC 60364-1 or applicable national/local regulations for electrical installation and guidelines.

However, PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC-system operation (such as the use of parity checking, self-testing diagnostics, etc.), are addressed.

The object of this standard is

- to establish the definitions and identify the principal characteristics relevant to the selection and application of PLCs and their associated peripherals;
- to specify the minimum requirements for functional, electrical, mechanical, environmental and construction characteristics, service conditions, safety, EMC, user programming and tests applicable to PLCs and the associated peripherals.

This standard also specifies

- a) service, storage and transportation requirements for PLCs and their associated peripherals (Clause 4);
- b) functional requirements for PLCs and their associated peripherals (Clause 5);