

*Institute of Environmental Sciences and Technology*

## **IEST-RP-CC036.1**

Contamination Control Division  
Recommended Practice 036.1

# Testing Fan Filter Units



2340 S. Arlington Heights Road, Suite 620  
Arlington Heights, IL 60005-4510  
Phone: (847) 981-0100 • Fax: (847) 981-4130  
E-mail: [information@iest.org](mailto:information@iest.org) • Web: [www.iest.org](http://www.iest.org)

---

**NOTICE AND DISCLAIMER:** This Recommended Practice is published by the Institute of Environmental Sciences and Technology (IEST) to advance the technical and engineering sciences. Use of this document is entirely voluntary, and determination of its applicability and suitability for any particular use is solely the responsibility of the user. Use of this Recommended Practice does not imply any warranty or endorsement by IEST.

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among all persons participating in the development of this document.

IEST standards, recommended practices, and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and seeks out the views of persons who have an interest in the topic covered by this publication. While IEST administers the process to promote fairness in the development of consensus, the organization does not write the document and does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in IEST standards, recommended practices, and guideline publications.

IEST disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. IEST disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of the particular purposes or needs of users of the document. IEST does not guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, IEST is not undertaking to render professional or other services for or on behalf of any person or entity, nor is IEST undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

IEST has no power, nor does it undertake to police or enforce compliance with the contents of this document. IEST does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to IEST and is solely the responsibility of the certifier or maker of the statement.

**PROPOSAL FOR IMPROVEMENT:** The Working Groups of the Institute of Environmental Sciences and Technology are continually working on improvements to their Recommended Practices and Reference Documents. Suggestions from users of these documents are welcome. If you have a suggestion regarding this document, please use the online Proposal for Improvement form found on the IEST website at [www.iest.org](http://www.iest.org).

This Recommended Practice was prepared by and is under the jurisdiction of Working Group 36 of the IEST Contamination Control Division.

Copyright © 2014 by the Institute of Environmental Sciences and Technology

First printing, September 2014

ISBN 978-1-937280-13-0

Institute of Environmental Sciences and Technology  
Arlington Place One  
2340 S. Arlington Heights Road, Suite 620  
Arlington Heights, IL 60005-4510  
Phone: (847) 981-0100 • Fax: (847) 981-4130

---

# Testing Fan Filter Units

## IEST-RP-CC036.1

### CONTENTS

#### SECTION

1	SCOPE AND LIMITATIONS .....	4
2	REFERENCES .....	4
3	TERMS AND DEFINITIONS .....	6
4	GENERAL DISCUSSION OF FAN FILTER UNITS .....	8
5	TEST REQUIREMENTS AND CONDITIONS .....	10
6	VOLUMETRIC AIRFLOW .....	11
7	ELECTRIC POWER USAGE .....	12
8	TOTAL PRESSURE .....	13
9	AIRFLOW UNIFORMITY .....	13
10	SOUND POWER LEVELS .....	14
11	REPORTING TEST RESULTS .....	14

#### FIGURE

FIGURE 1—TYPICAL FAN FILTER UNIT AND DIAGRAM.....	8
FIGURE 2—TYPICAL AIRFLOW CHAMBER. ....	11
FIGURE B1—TEST SETUP TO MEASURE AIRFLOW THROUGH THE FFU.....	17
FIGURE C1—TEST SETUP TO MEASURE SOUND PRESSURE LEVELS. ....	18

#### APPENDIX

APPENDIX A—OTHER DESIGN CONSIDERATIONS: AEROSOL INJECTION AND CHALLENGE UNIFORMITY .....	16
APPENDIX B—ALTERNATIVE METHOD FOR MEASUREMENT OF VOLUMETRIC AIRFLOW, ELECTRIC POWER PARAMETERS, AND STATIC PRESSURE .....	17
APPENDIX C—ALTERNATIVE METHOD FOR SOUND POWER LEVEL MEASUREMENTS .....	18