

# Methods for Determining Quality of Subsurface Injection Water Using Membrane Filters

This NACE International standard represents a consensus of those individual members who have reviewed this document, its scope, and provisions. Its acceptance does not in any respect preclude anyone, whether he or she has adopted the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not in conformance with this standard. Nothing contained in this NACE standard is to be construed as granting any right, by implication or otherwise, to manufacture, sell, or use in connection with any method, apparatus, or product covered by letters patent, or as indemnifying or protecting anyone against liability for infringement of letters patent. This standard represents minimum requirements and should in no way be interpreted as a restriction on the use of better procedures or materials. Neither is this standard intended to apply in all cases relating to the subject. Unpredictable circumstances may negate the usefulness of this standard in specific instances. NACE assumes no responsibility for the interpretation or use of this standard by other parties and accepts responsibility for only those official NACE interpretations issued by NACE in accordance with its governing procedures and policies which preclude the issuance of interpretations by individual volunteers.

Users of this NACE standard are responsible for reviewing appropriate health, safety, environmental, and regulatory documents and for determining their applicability in relation to this standard prior to its use. This NACE standard may not necessarily address all potential health and safety problems or environmental hazards associated with the use of materials, equipment, and/or operations detailed or referred to within this standard. Users of this NACE standard are also responsible for establishing appropriate health, safety, and environmental protection practices, in consultation with appropriate regulatory authorities if necessary, to achieve compliance with any existing applicable regulatory requirements prior to the use of this standard.

**CAUTIONARY NOTICE:** NACE standards are subject to periodic review, and may be revised or withdrawn at any time in accordance with NACE technical committee procedures. NACE requires that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of initial publication and subsequently from the date of each reaffirmation or revision. The user is cautioned to obtain the latest edition. Purchasers of NACE standards may receive current information on all standards and other NACE publications by contacting the NACE *FirstService* Department, 15835 Park Ten Place, Houston, TX 77084-5145 (tel: +1 281-228-6200, email: [firstservice@nace.org](mailto:firstservice@nace.org)).

## ABSTRACT

*This standard method is provided to improve available water quality data. This standard describes two methods for evaluating water quality for subsurface injection: Procedure A—rate versus cumulative volume test (for water-quality monitoring) and Procedure B—suspended solids test (for diagnosis or monitoring). The methods describe the apparatus required, test conditions, test procedures, reporting procedures, and supplementary tests. This standard is maintained by Task Group 408.*

## KEYWORDS

*Water quality, subsurface injection, test methods.*

# Foreword

Corrosion engineers in the oil- and gas-producing industry are often responsible for evaluating and controlling injection water quality. Water quality data may be inadequate, misleading, or difficult to interpret. This standard method is provided to improve available water quality data.

This standard was originally prepared in 1973 by NACE Task Group T-1C-12, revised in 1976, reaffirmed in 1983, and revised in 1984 and 1992 by T-1C-20, components of Unit Committee T-1C, "Detection of Corrosion in Oilfield Equipment." T-1C was combined with T-1D, "Corrosion Monitoring and Control of Corrosion Environments in Petroleum Production Operations." This standard was revised by T-1D-47 in 1999, reaffirmed in 2005 by Specific Technology Group (STG) 31, "Oil and Gas Production—Corrosion and Scale Inhibition," and revised in 2014 by Task Group (TG) 408, "Review and Revise as Necessary NACE Standard TM0173-2005." This standard is issued by NACE International under the auspices of STG 31.

In NACE standards, the terms **shall**, **must**, **should**, and **may** are used in accordance with the definitions of these terms in the NACE Publications Style Manual. The terms **shall** and **must** are used to state a requirement, and are considered mandatory. The term **should** is used to state something good and is recommended, but is not considered mandatory. The term **may** is used to state something considered optional.

# Methods for Determining Quality of Subsurface Injection Water Using Membrane Filters

1.	General .....	4
2.	Definitions .....	4
3.	Description of Methods .....	4
4.	Test Apparatus .....	6
5.	Preparation for Testing .....	9
6.	Test Conditions.....	9
7.	Test Procedures .....	10
8.	Reporting Test Data .....	12
9.	Reference.....	14
10.	Bibliography .....	14
	Appendix A: Microscopic Examination (Nonmandatory) .....	14
	Appendix B: Microchemical Spot Test Methods (Nonmandatory).....	16
	Appendix C: Supplementary Suspended Solids Test Methods (Nonmandatory).....	18

## Figures

Figure 1: Example of a membrane filter holder for 47 mm (1.8 in) membrane filter, made of corrosion-resistant materials capable of withstanding upstream pressure of 14 MPa (2,000 psig). The holder is designed for quick connection to a water-handling system to prevent detrimental aeration effects and for rapid assembly or dismantling. ....	6
Figure 2: Membrane filter test apparatus showing membrane filter holder from Figure 1 connected to water-handling system. The 6.4 mm (0.25 in) nominal OD (¼ in NPT) block and needle valves near the top keep system pressure within set limits. Above the membrane filter holder is a quick-opening toggle valve to allow immediate full-stream flow vital to timing accuracy. Length of tubing between the source and the apparatus should be minimized to prevent forming a “dead leg.” .....	7
Figure 3: Two-stage test apparatus with pressure gauge and regulator for repressurizing and testing sample from reservoir rather than water-handling system (Figure 2), used mainly when sample point cannot be easily adapted to on-stream application.....	8
Figure 4: Example of a Graphic Representation of Water Quality.....	11
Figure 5: Apparatus for various washings or extractions by vacuum filtration. The vacuum source may be either a vacuum pump or a water aspirator.....	12

## Tables

Table 1: Example of Membrane Filter Test Data .....	13
---	----