



Calculation and Measurement of Direct and Scattered Gamma Radiation from LWR Nuclear Power Plants

REAFFIRMED

April 23, 2020

ANSI/ANS-6.6.1-2015 (R2020)

An American National Standard

This standard has been reviewed and reaffirmed with the recognition that it may reference other standards and documents that may have been superseded or withdrawn. The requirements of this document will be met by using the version of the standards and documents referenced herein. It is the responsibility of the user to review each of the references and to determine whether the use of the original references or more recent versions is appropriate for the facility. Variations from the standards and documents referenced in this standard should be evaluated and documented. This standard does not necessarily reflect recent industry initiatives for risk informed decision-making or a graded approach to quality assurance. Users should consider the use of these industry initiatives in the application of this standard.

Published by the
American Nuclear Society
555 N. Kensington Ave
La Grange Park, IL 60526



ANSI/ANS-6.6.1-2015

**American National Standard
Calculation and Measurement of Direct and Scattered
Gamma Radiation from LWR Nuclear Power Plants**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-6.6.1**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved August 21, 2015
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under the procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Responses to inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) should be sent to the Scientific Publications and Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**



This document is copyright protected.

Copyright © 2015 by American Nuclear Society.

Any part of this standard may be quoted. Credit lines, should read “Extracted from American National Standard ANSI/ANS-6.6.1-2015 with permission of the publisher, the American Nuclear Society.”
Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

Inquiry Requests

The American Nuclear Society (ANS) Standards Committee will provide responses to inquiries about requirements, recommendations, and/or permissive statements (i.e., “shall,” “should,” and “may,” respectively) in American National Standards that are developed and approved by ANS. Responses to inquiries will be provided according to the Policy Manual for the ANS Standards Committee. Nonrelevant inquiries or those concerning unrelated subjects will be returned with appropriate explanation. ANS does not develop case interpretations of requirements in a standard that are applicable to a specific design, operation, facility, or other unique situation only and therefore is not intended for generic application.

Responses to inquiries on standards are published in ANS’s magazine, *Nuclear News*, and are available publicly on the ANS Web site or by contacting the ANS Scientific Publications and Standards Department.

Inquiry Format

Inquiry requests shall include the following:

- (1) the name, company name if applicable, mailing address, and telephone number of the inquirer;
- (2) reference to the applicable standard edition, section, paragraph, figure, and/or table;
- (3) the purpose(s) of the inquiry;
- (4) the inquiry stated in a clear, concise manner;
- (5) a proposed reply, if the inquirer is in a position to offer one.

Inquiries should be addressed to

American Nuclear Society
ATTN: Scientific Publications and Standards Department
555 N. Kensington Avenue
La Grange Park, IL 60526

or standards@ans.org

Foreword

(This foreword is not a part of American National Standard, “Calculation and Measurement of Direct and Scattered Gamma Radiation from LWR Nuclear Power Plants,” ANSI/ANS-6.6.1-2015.)

In mid-1973, a need for a standard on this subject was identified by D. K. Trubey, chairman of ANS-6. The proposed standard had been listed among those having a high priority by the Atomic Energy Commission Directorate of Regulatory Standards. The project was assigned by the NTAB Executive Committee in September 1973. Working Group ANS-6.6 was formed and E. A. Warman was appointed chairman in September 1973. The first meeting of the working group was held in November 1973. Twelve subsequent meetings were held from February 1974 through June 1978.

When preparing the initial version of this standard, the 1973 working group provided a series of reference calculations with which a radiation analyst should compare results obtained by the method he/she elected to use in a given application. Comparison with the results of these reference calculations is intended to provide some assurance that the methods being considered by this standard’s user produce results that are in reasonable agreement with those of other methods. These reference calculations are intentionally simplistic to make this comparison effort easier to accomplish.

The first working draft was completed in June 1975. A revised working draft was distributed for initial review by ANS-6 chairs in June 1976. The completed first draft (Draft 1) was submitted to ANS-6 for ballot in September 1977. This draft was unanimously approved in subsequent balloting by ANS-6 subcommittee chairs, with the sole negative ballot being changed to affirmative after resolution of comments. A reorganized working group, ANS-6.6.1, was established in 2012 to reconsider the status of the standard. In June 2013, that working group recommended revisions of the standard to (a) correct editorial errors, (b) update the list of referenced documents, (c) update the definitions and units of the dose terms, (d) update Figs. 6.3 through 6.8 to include dose rate results for the reference calculations computed based on a modern Monte Carlo (MCNP5) computer program, and (e) incorporate three new tables (Tables 6.3, 6.4, and 6.5) providing the MCNP5-computed dose rate results and their relative statistical uncertainty.

This standard addresses contained sources of direct and scattered radiation and specifically excludes effluent releases and accident sources. Measurements at some operating plants, which have no local shielding to reduce reactor cavity nozzle inspection port streaming, have indicated that localized streaming can be measurable outside the containment. Such localized streaming effects are not addressed in this standard.

Particular emphasis is placed on the direct and scattered radiation from ^{16}N sources in boiling water reactors (BWRs). This emphasis reflects the fact that analysis and ^{16}N measurement of radiation associated with sources at BWRs was identified as a major area of interest in establishing priority for development of this standard. The three appendices to the standard are included as examples of the type of measurements and analyses that have been performed in connection with the ^{16}N sources at BWRs. In Appendices A and B, the assumption is made that the observed dose rates are entirely the result of ^{16}N activity. The net effect of this assumption is to increase the amount of conservatism in the quantification of the source terms, in that other radiations are included in the measurements from which the ^{16}N source terms are developed.

This standard might reference documents and other standards that have been superseded or withdrawn at the time the standard is applied. A statement has been included in Sec. 8, References,” that provides guidance on the use of references.

This standard does not incorporate the concepts of generating risk-informed insights, performance-based requirements, or a graded approach to quality assurance. The user is advised that one or more of these techniques could enhance the application of this standard.

Working Group ANS-6.6.1 of the ANS Standards Committee had the following membership:

R. S. Amato (Chair), *Bechtel Marine Propulsion Corp.*
J. Bevelacqua, *Bevelacqua Resources Corp.*
P. Caracappa, *Rensselaer Polytechnic Institute*
J. Chen, *Westinghouse Electric Company, LLC*
B. Hinderliter, *University of Minnesota–Duluth*
S. Wang, *Westinghouse Electric Company, LLC*

The membership of the Radiation Protection and Shielding Subcommittee, at the time of the approval of this standard, was as follows:

C. Sanders (Chair), *UNLV/Sanders Engineering*
A. Alpan, *Westinghouse Electric Company*
R. S. Amato, *Bechtel Marine Propulsion Corp.*
P. Bergstrom, *National Institute of Standards & Technology*
C. Beyer, *Pacific Northwest National Laboratory*
D. Dudziak, *Los Alamos National Laboratory*
M. K. Gupta, *AECOM-Professional Solutions*
N. E. Hertel, *Georgia Institute of Technology*
B. Hinderliter, *University of Minnesota–Duluth*
S. Nathan, *Savannah River Nuclear Solutions*
J. Ryman, *Individual*
A. Simpkins, *Dade Moeller & Associates*
R. M. Westfall, *Individual*

The membership of the Safety and Radiological Analyses Consensus Committee, at the time of the review and approval of this standard, was as follows:

A. O. Smetana (Chair), *Savannah River National Laboratory*
A. Weitzberg (Vice Chair), *Individual*
F. A. Alpan, *Westinghouse Electric Company, LLC*
R. S. Amato, *Bechtel Marine Propulsion Corp.*
M. C. Brady Raap, *Pacific Northwest National Laboratory*
R. R. Brey, *Health Physics Society (Employed by Idaho State University)*
R. E. Carter, *Individual*
D. M. Cokinos, *Brookhaven National Laboratory*
M. L. Corradini, *National Council on Radiation Protection & Measurements (Employed by University of Wisconsin–Madison)*
D. J. Dudziak, *Los Alamos National Laboratory*
M. K. Gupta, *AECOM-Professional Solutions*
N. E. Hertel, *Georgia Institute of Technology*
P. Hulse, *Sellafield, LTD.*
K. Morrell, *Savannah River Nuclear Solutions*
D. E. Palmrose, *U.S. Nuclear Regulatory Commission*
C. T. Rombough, *CTR Technical Services, Inc.*
C. E. Sanders, *University of Las Vegas–Nevada*

Contents

Section	Page
1 Scope.....	1
2 Applicable documents	1
3 Terms and definitions	1
3.1 Acronyms	1
3.2 Shall, should, and may	2
3.3 Definitions	2
4 Requirements	3
5 Dose assessment guidelines	4
6 Calculations	4
6.1 General introduction	4
6.2 Sources	5
6.2.1 Sources inside shielded buildings	5
6.2.2 Sources outside shielded buildings	5
6.3 Source modeling (mathematical representations)	5
6.3.1 Source strengths and assumptions.....	6
6.3.2 Geometric considerations.....	7
6.4 Geometric modeling (shielding and plant layout).....	8
6.5 Site topography.....	8
6.6 Radiation transport methods	9
6.6.1 Acceptable methods.....	9
6.6.2 Reference calculations	10
6.6.2.1 Reference calculations I.1	10
6.6.2.2 Reference calculations I.2	10
6.6.2.3 Reference calculations II.1	10
6.6.2.4 Reference calculations II.2.....	10
7 Measurement constraints and interpretation of data	14
7.1 General considerations	14
7.2 Measurement techniques.....	21
7.2.1 Thermoluminescence dosimeters.....	21
7.2.2 Ionization chambers	22
7.2.3 Gamma-ray spectrometry.....	23
7.3 Measurement techniques summary	24
8 References.....	24
Tables	
Table 6.1	6
Table 6.2	7
Table 6.3	13
Table 6.4	13
Table 6.5	14
Table A.1	28
Table A.2	29
Table B.1	35

Table B.2	35
Table B.3	36
Table B.4	36
Table B.5	36
Table B.6	36

Figures

Fig. 6.1	Geometric configurations for Reference Problem I.1 and I.2	11
Fig. 6.2	Geometric configurations for Reference Problem II.1 and II.2	11
Fig. 6.3	Scattered dose rate as a function of horizontal distance for Reference Problem I.1	15
Fig. 6.4	Total dose rate as a function of horizontal distance for Reference Problem I.1	16
Fig. 6.5	Scattered dose rate as a function of horizontal distance for Reference Problem I.2	17
Fig. 6.6	Total dose rate as a function of horizontal distance for Reference Problem I.2	18
Fig. 6.7	Total dose rate as a function of horizontal distance for Reference Problem II.1	19
Fig. 6.8	Total dose rate as a function of horizontal distance for Reference Problem II.2	20
Fig. A.1	Dose point designations and locations	29
Fig. B.1	Cooper nuclear power station	33
Fig. B.2	Duane Arnold Energy Center	34
Fig. B.3	Steam line radiation monitor readings	35
Fig. C.1	Distance from source (meters)	38

Appendices

Appendix A	Semi-Empirical Determination of ¹⁶ N-Specific Activity at an Operating Boiling Water Reactor.....	27
Appendix B	Estimates of ¹⁶ N-Specific Activity from Main Stream Line Measurements at a 1600-MWt and a 2400-MWt Boiling Water Reactor.....	30
Appendix C	Measurements of ¹⁶ N Gamma Radiation Fields Near Operating Boiling Water Reactors	37