

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electricity metering equipment (AC) – General requirements, tests and test conditions –

Part 31: Product safety requirements and tests

Équipement de comptage de l'électricité (CA) – Exigences générales, essais et conditions d'essai –

Partie 31: Exigences et essais sur la sécurité de produit



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electricity metering equipment (AC) – General requirements, tests and test conditions –

Part 31: Product safety requirements and tests

Équipement de comptage de l'électricité (CA) – Exigences générales, essais et conditions d'essai –

Partie 31: Exigences et essais sur la sécurité de produit

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 19.080; 91.140.50

ISBN 978-2-8322-3769-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope and object.....	12
1.1 Scope	12
1.2 Object.....	13
1.2.1 Aspects included in scope	13
1.2.2 Aspects excluded from scope	13
1.3 Verification.....	14
1.4 Environmental conditions	14
1.4.1 Normal environmental conditions	14
1.4.2 Extended environmental conditions	14
1.4.3 Extreme environmental conditions	15
2 Normative references	15
3 Terms and definitions	16
3.1 Equipment and states of equipment	16
3.2 Parts and accessories.....	17
3.3 Quantities	19
3.4 Tests	21
3.5 Safety terms	21
3.6 Insulation	25
3.7 Terms related to switches of metering equipment.....	29
4 Tests	31
4.1 General.....	31
4.2 Type test – sequence of tests	31
4.3 Reference test conditions.....	32
4.3.1 Atmospheric conditions.....	32
4.3.2 State of the equipment.....	32
4.4 Testing in single fault condition	36
4.4.1 General	36
4.4.2 Application of fault conditions	36
4.4.3 Duration of tests	38
4.4.4 Conformity after application of fault conditions.....	38
5 Information and marking requirements.....	39
5.1 General.....	39
5.2 Labels, signs and signals	41
5.2.1 General	41
5.2.2 Durability of markings	43
5.3 Information for selection	43
5.3.1 General	43
5.3.2 General information	43
5.3.3 Information related to meters / metering elements	44
5.3.4 Information related to stand-alone tariff-and load control equipment	44
5.3.5 Information related to supply control and load control switches.....	44
5.4 Information for installation and commissioning	44
5.4.1 General	44
5.4.2 Handling and mounting	45

5.4.3	Enclosure	45
5.4.4	Connection	45
5.4.5	Protection	47
5.4.6	Auxiliary power supply	48
5.4.7	Supply for external devices	48
5.4.8	Batteries	48
5.4.9	Self-consumption	48
5.4.10	Commissioning	49
5.5	Information for use	49
5.5.1	General	49
5.5.2	Display, push buttons and other controls	49
5.5.3	Switches	49
5.5.4	Connection to user's equipment	50
5.5.5	External protection devices	50
5.5.6	Cleaning	50
5.6	Information for maintenance	50
6	Protection against electrical shock	50
6.1	General requirements	50
6.2	Determination of accessible parts	51
6.2.1	General	51
6.2.2	Examination	51
6.2.3	Openings above parts that are hazardous live	52
6.2.4	Openings for pre-set controls	52
6.2.5	Wiring terminals	53
6.3	Limit values for accessible parts	53
6.3.1	General	53
6.3.2	Levels in normal condition	53
6.3.3	Levels in single fault condition	53
6.4	Primary means of protection (protection against direct contact)	56
6.4.1	General	56
6.4.2	Equipment case	56
6.4.3	Basic insulation	56
6.4.4	Impedance	56
6.5	Additional means of protection in case of single fault conditions (protection against indirect contact)	57
6.5.1	General	57
6.5.2	Protective bonding	57
6.5.3	Supplementary insulation and reinforced insulation	61
6.5.4	Protective impedance	61
6.5.5	Automatic disconnection of the supply	61
6.5.6	Current- or voltage-limiting device	62
6.6	Connection to external circuits	62
6.6.1	General	62
6.6.2	Terminals for external circuits	63
6.6.3	Terminals for stranded conductors	63
6.7	Insulation requirements	63
6.7.1	General – Electrical stresses, overvoltages and overvoltage categories	63
6.7.2	The nature of insulation	64
6.7.3	Insulation requirements for mains-circuits	68

6.7.4	Insulation requirements for non-mains-circuits	74
6.7.5	Insulation in circuits not addressed in 6.7.3 or 6.7.4	78
6.7.6	Reduction of transient overvoltages by the use of overvoltage limiting devices	84
6.8	Insulation requirements between circuits and parts	84
6.9	Constructional requirements for protection against electric shock	88
6.9.1	General	88
6.9.2	Insulating materials	88
6.9.3	Colour coding	88
6.9.4	Equipment case	88
6.9.5	Terminal blocks	89
6.9.6	Insulating materials of supply control and load switches	89
6.9.7	Terminals	90
6.9.8	Requirements for current circuits	92
6.10	Safety related electrical tests	99
6.10.1	Overview	99
6.10.2	Test methods	101
6.10.3	Testing of voltage circuits	104
6.10.4	Dielectric tests	106
6.10.5	Electrical tests on current circuits of direct connected meters without supply control switches (SCSs)	112
6.10.6	Electrical tests on current circuits of direct connected meters with SCSs	113
6.10.7	Electrical tests on load control switches (LCSs)	119
7	Protection against mechanical hazards	122
7.1	General	122
7.2	Sharp edges	122
7.3	Provisions for lifting and carrying	123
8	Resistance to mechanical stresses	123
8.1	General	123
8.2	Spring hammer test	123
9	Protection against spread of fire	124
9.1	General	124
9.2	Eliminating or reducing the sources of ignition within the equipment	125
9.3	Containment of fire within the equipment, should it occur	125
9.3.1	General	125
9.3.2	Constructional requirements	126
9.4	Limited-energy circuit	126
9.5	Overcurrent protection	128
10	Equipment temperature limits and resistance to heat	128
10.1	Surface temperature limits for protection against burns	128
10.2	Temperature limits for terminals	129
10.3	Temperatures of internal parts	130
10.4	Temperature test	132
10.5	Resistance to heat	133
10.5.1	Non-metallic enclosures	133
10.5.2	Insulating materials	134
11	Protection against penetration of dust and water	134
12	Protection against liberated gases and substances explosion and implosion – Batteries and battery charging	136

13	Components and sub-assemblies	136
13.1	General.....	136
13.2	Mains transformers tested outside equipment	138
13.3	Printed wiring boards	138
13.4	Components bridging insulation	138
13.5	Circuits or components used as transient overvoltage limiting devices	138
14	Hazards resulting from application – Reasonably foreseeable misuse	138
15	Risk assessment	139
Annex A	(normative) Measuring circuits for touch current	140
A.1	Measuring circuit for a.c. with frequencies up to 1 MHz and for d.c.	140
A.2	Measuring circuits for sinusoidal a.c. with frequencies up to 100 Hz and for d.c.	141
A.3	Current measuring circuit for electrical burns at high frequencies.....	141
A.4	Current measuring circuit for wet location	142
Annex B	(informative) Examples for insulation between parts	143
B.1	Insulation between parts – Example 1	143
B.2	Insulation between parts – Example 2.....	144
B.3	Insulation between parts – Example 3.....	145
B.4	Insulation between parts – Example 4.....	146
B.5	Insulation between parts – Example 5.....	147
Annex C	(informative) Examples for direct connected meters equipped with supply control and load control switches	149
Annex D	(normative) Test circuit diagram for the test of long term overvoltage withstand	151
Annex E	(normative) Test circuit diagram for short current test on the current circuit of direct connected meters.....	152
Annex F	(informative) Examples for voltage tests.....	154
Annex G	(normative) Additional a.c. voltage tests for electromechanical meters	158
Annex H	(normative) Test equipment for cable flexion and pull test	159
Annex I	(informative) Routine tests	161
I.1	General.....	161
I.2	Protective earth	161
I.3	AC power-frequency high-voltage test for mains-circuits	161
I.4	Mains-circuits with voltage limiting devices	161
Annex J	(informative) Examples of battery protection.....	162
Annex K	(informative) Rationale for specifying overvoltage category III	163
K.1	Transient overvoltage requirements in TC 13 standards.....	163
K.2	Electricity meters mentioned in basic safety publications and group safety publications	163
K.2.1	IEC 60664-1	163
K.2.2	IEC 60364-4-44	164
K.2.3	IEC 61010-1	164
K.3	Conclusion.....	165
Annex L	(informative) Overview of safety aspects covered.....	166
Annex M	(informative) Index of defined terms	181
Bibliography	184
Figure 1	– Measurements through openings in enclosures	52

Figure 2 – Maximum duration of short-term accessible voltages in single fault condition (see 6.3.3 a))	54
Figure 3 – Capacitance level versus voltage in normal condition and single fault condition (see 6.3.2 c) and 6.3.3 c))	55
Figure 4 – Acceptable arrangements of protection means against electric shock.....	57
Figure 5 – Examples of binding screw assemblies	59
Figure 6 – Distance between conductors on an interface between two layers.....	72
Figure 7 – Distance between adjacent conductors along an interface of an inner layer	72
Figure 8 – Distance between adjacent conductors located between the same two layers.....	74
Figure 9 – Example of recurring peak voltage	82
Figure 10 – Flowchart of safety related electrical tests.....	100
Figure 11 – Flow chart to explain the requirements for protection against the spread of fire	125
Figure 12 – Ball-pressure test apparatus.....	134
Figure 13 – Flow chart for conformity options 13.1 a), b), c) and d).....	137
Figure A.1 – Measuring circuit for a.c. with frequencies up to 1 MHz and for d.c.	140
Figure A.2 – Measuring circuits for sinusoidal a.c. with frequencies up to 100 Hz and for d.c.	141
Figure A.3 – Current measuring circuit for electrical burns	142
Figure A.4 – Current measuring circuit for wet contact	142
Figure B.1 – Insulation between parts – Example 1	143
Figure B.2 – Insulation between parts – Example 2.....	144
Figure B.3 – Insulation between parts – Example 3.....	145
Figure B.4 – Insulation between parts – Example 4.....	146
Figure B.5 – Insulation between parts – Example 5.....	147
Figure C.1 – Single phase two wire meter with UC2 SCS and 25A LCS	149
Figure C.2 – Three phase four wire meter with UC2 SCS and 2A auxiliary control switch	150
Figure D.1 – Circuit for three-phase four-wire meters to simulate long term overvoltage, voltage moved to L3.....	151
Figure D.2 – Voltages at the meter under test.....	151
Figure E.1 – Test circuit for verification of short-time withstand current test on current circuits with and without supply control switches	152
Figure E.2 – Example of short-circuit carrying test record in the case of a single-pole equipment on single-phase a.c.	153
Figure F.1 – Test arrangement for voltage tests: 3 phase 4 wire direct connected meter with supply control and load control switches	154
Figure F.2 – Test arrangement for voltage tests: 3 phase 4 wire transformer connected meter.....	156
Figure H.1 – Test equipment for cable flexion and pull test (see 6.9.7.3)	159
Figure J.1 – Non-rechargeable battery protection.....	162
Figure J.2 – Rechargeable battery protection.....	162
Table 1 – Test copper conductors for current and switch terminals	35
Table 2 – Information requirements.....	40

Table 3 – IEC 60417 symbols and ISO 7000 that may be used on metering equipment.....	42
Table 4 – Tightening torque for binding screw assemblies	60
Table 5 – Multiplication factors for clearance for altitudes up to 5 000 m.....	64
Table 6 – Overview of clauses specifying requirements and tests for insulations	67
Table 7 – Nominal / rated voltages and rated impulse voltages	68
Table 8 – Clearances for mains-circuits	69
Table 9 – Creepage distances for mains-circuits	70
Table 10 – Test voltages for solid insulation in mains-circuits	71
Table 11 – Test voltages for testing long-term stress of solid insulation in mains-circuits.....	71
Table 12 – Minimum values for distance or thickness of solid insulation.....	73
Table 13 – Clearances and test voltages for non-mains-circuits derived from mains-circuits of overvoltage category III	75
Table 14 – Creepage distances for non-mains-circuits	76
Table 15 – Minimum values for distance or thickness (see 6.7.4.4.2 to 6.7.4.4.4)	77
Table 16 – Clearance values for the calculation of 6.7.5.2	80
Table 17 – Test voltages based on clearances.....	81
Table 18 – Clearances for basic insulation in circuits having recurring peak voltages	83
Table 19 – Isolation classes for non-mains-circuits	85
Table 20 – Insulation requirements between any two circuits	86
Table 21 – Summary of requirements for current circuits of direct connected meters without SCS.....	95
Table 22 – Summary of requirements for current circuits of direct connected meters with SCS.....	96
Table 23 – Summary of requirements for load control switches	98
Table 24 – Correction factors according to test site altitude for test voltages for clearances	104
Table 25 – AC voltage test.....	109
Table 26 – Test sequence and sample plan for supply control switches	113
Table 27 – Power factor ranges of the test circuit	116
Table 28 – Test sequence and sample plan for load control switches.....	120
Table 29 – Limits of maximum available current.....	127
Table 30 – Values for overcurrent protection devices	127
Table 31 – Surface temperature limits in normal condition	129
Table 32 – Temperature limits for terminals	130
Table 33 – Maximum measured total temperatures for internal materials and components	131
Table G.1 – AC voltage tests of electromechanical meters.....	158
Table H.1 – Test values for flexion and pull-out tests for round copper conductors	160
Table L.1 – Overview of safety aspects.....	166

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING EQUIPMENT (AC) –
GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –****Part 31: Product safety requirements and tests****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62052-31 has been prepared by IEC technical committee 13: Electrical energy measurement and control.

This bilingual version (2017-01) corresponds to the monolingual English version, published in 2015-09.

The text of this standard is based on the following documents:

FDIS	Report on voting
13/1639/FDIS	13/1645/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 62052 series, under the general title *Electricity metering equipment (AC) – General requirements, tests and test conditions*, can be found on the IEC website.

In this standard, the following print types are used:

- requirements and definitions: in roman type;
- NOTES: in smaller roman type;
- *conformity and tests: in italic type.*

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

NOTE 1 The following text is based on IEC Guide 104, ISO/IEC Guide 51 and IEC 60255-27:2013.

The IEC addresses safety aspects by establishing *basic*, *group* and *product* safety publications.

A *basic safety publication* covers a specific safety-related matter, applicable to many electrotechnical products. It is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies. One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of basic safety publications will not apply unless specifically referred to or included in the relevant publications.

A *group safety publication* covers all safety aspects of a specific group of products within the scope of two or more product TCs. Group safety publications are primarily intended to be stand-alone product safety publications, but may also be used by TCs as source material in the preparation of their publications.

A *product safety publication* covers all safety aspects of one or more products within the scope of a single product TC.

Existing product standards established by TC 13 include a range of safety requirements, test methods and test conditions. However, an important requirement of IEC Guide 104:2010, 5.2.3 has not been met so far:

“Safety aspects and performance aspects should not be covered in the same publication, as this makes it difficult to assess conformity with safety requirements alone. If, exceptionally, there are reasons to cover them in the same publication, safety aspects and performance aspects shall be clearly distinguished from each other. If there are performance criteria which have safety implications, these are considered to be safety aspects and this shall be made clear in the publication.”

In addition, some important aspects of product safety, such as safety under single fault conditions, have not been covered so far.

The objectives of the development of this International Standard are the following:

- to specifically reference and include relevant requirements, test methods or test conditions of relevant basic safety publications so that they become applicable;
- to specifically reference and include – where appropriate, in a modified form – relevant requirements, test methods or test conditions of relevant group safety publications;
- to consider the latest developments in the technology used for the design and manufacture of equipment for electrical energy measurement and control;
- to remove any ambiguity resulting from the lack of a comprehensive product safety standard for products in the Scope of TC 13;
- to achieve a uniform approach to product safety throughout the international metering industry.

This *product safety standard* is based on, among others, the following:

- the *basic safety standard* IEC 60664-1:2007, established by TC 109;
- standards from the IEC 60364 series related to electrical installations of buildings, established by TC 64;
- the *group safety standard* IEC 61010-1:2010 established by TC 66;

- the *group safety standard* IEC 62477-1:2012 established by TC 22;
- IEC 60255-27:2013, a *product safety standard* for measuring relays and protection equipment, established by TC 95. These products are similar in their design and to some extent in their use in equipment for electrical energy measurement and control.

To facilitate the use of this standard, an integral text has been prepared, with appropriate 539 references to source documents.

This standard cancels and replaces the safety requirements specified in earlier standards established by IEC TC 13. See also Annex L (Informative).

NOTE 2 When this standard is published, an amendment to the relevant standards affected by this standard in IEC 62052, IEC 62053 and IEC 62054 will be published, to indicate which parts of those standards are replaced / cancelled by this standard.

Being a product safety standard, this standard takes precedence over the group safety standards IEC 61010-1:2010 and IEC 62477-1:2012.

ELECTRICITY METERING EQUIPMENT (AC) – GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –

Part 31: Product safety requirements and tests

1 Scope and object

1.1 Scope

This part of IEC 62052 specifies product safety requirements for equipment for electrical energy measurement and control.

NOTE 1 For other requirements, see the relevant standards.

This International Standard applies to newly manufactured metering equipment designed to measure and control electrical energy on 50 Hz or 60 Hz networks with a voltage up to 600 V, where all functional elements, including add-on modules are enclosed in or form a single case.

NOTE 2 The voltage mentioned above is the voltage line-to-neutral derived from nominal voltages. See Table 7.

This International Standard also applies to metering equipment containing supply and load control switches, but only those which are electromechanical in operation.

NOTE 3 For components and sub-assemblies, see Clause 13.

When such equipment is designed to be installed in a specified matching socket, then the requirements apply to, and the tests shall be performed on, equipment installed in its specified matching socket. However, requirements for sockets and inserting / removing the meters from the socket are outside the scope of this standard.

This International Standard is also applicable to auxiliary input and output circuits.

NOTE 4 Examples are impulse inputs and outputs, control inputs and outputs, circuits for meter data exchange.

In this standard distinction is made between:

- electromechanical meters, static meters and equipment for tariff and load control;
- direct connected, current transformer operated, voltage and current transformer operated meters;
- protective class I and protective class II equipment;
- wall or cabinet mounted, rack mounted and panel mounted equipment;
- equipment intended for indoor use and outdoor use.

Equipment used in conjunction with equipment for electrical energy measurement and control may need to comply with additional safety requirements. See also Clause 13.

NOTE 5 Examples are telecommunication modems and customer information units.

This International Standard does not apply to:

- equipment where the voltage line-to-neutral derived from nominal voltages exceeds 600 V;
- portable meters;

NOTE 6 Portable meters are meters that are not permanently connected.