

# INTERNATIONAL STANDARD



---

**Industrial communication networks – Fieldbus specifications –  
Part 5-2: Application layer service definition – Type 2 elements**



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2019 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

**IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

**IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

**IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)**

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.



IEC 61158-5-2

Edition 4.0 2019-04

# INTERNATIONAL STANDARD



---

**Industrial communication networks – Fieldbus specifications –  
Part 5-2: Application layer service definition – Type 2 elements**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-6738-7

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications .....	10
1.3 Conformance .....	10
2 Normative references .....	10
3 Terms, definitions, symbols, abbreviated terms and conventions .....	12
3.1 ISO/IEC 7498-1 terms.....	12
3.2 ISO/IEC 8822 terms.....	13
3.3 ISO/IEC 9545 terms.....	13
3.4 ISO/IEC 8824-1 terms.....	13
3.5 Type 2 fieldbus data-link layer terms.....	13
3.6 Type 2 fieldbus application-layer specific definitions .....	13
3.7 Type 2 abbreviated terms and symbols .....	21
3.8 Conventions.....	22
3.8.1 Overview .....	22
3.8.2 General conventions.....	23
3.8.3 Conventions for class definitions .....	23
3.8.4 Conventions for service definitions .....	24
4 Common concepts.....	25
5 Data type ASE.....	25
5.1 General.....	25
5.2 Formal definition of data type objects.....	25
5.3 FAL defined data types .....	26
5.3.1 Fixed length types .....	26
5.3.2 String types .....	31
5.3.3 Structure types .....	32
5.4 Data type ASE service specification.....	36
6 Communication model specification.....	36
6.1 Concepts .....	36
6.1.1 General .....	36
6.1.2 General concepts .....	36
6.1.3 Relationships between ASEs .....	37
6.1.4 Naming and addressing .....	38
6.1.5 Data types .....	39
6.2 ASEs .....	46
6.2.1 Object management ASE.....	46
6.2.2 Connection manager ASE.....	154
6.2.3 Connection ASE .....	172
6.3 ARs .....	186
6.3.1 Overview .....	186
6.3.2 UCMM AR formal model .....	197
6.3.3 Transport AR formal model.....	199
6.3.4 AR ASE services .....	209
6.4 Summary of FAL classes .....	217

6.5 Permitted FAL services by AR type .....	218
Bibliography.....	220
Figure 1 – Overview of ASEs and object classes .....	38
Figure 2 – Addressing format using MAC, class, instance and attribute IDs .....	39
Figure 3 – Identity object state transition diagram .....	60
Figure 4 – Explicit and Implicit Setting interaction .....	63
Figure 5 – Static Assembly state transition diagram .....	67
Figure 6 – Dynamic Assembly state transition diagram .....	68
Figure 7 – Typical timing relationships for acknowledged data production.....	79
Figure 8 – Example of a COS system with two acking devices .....	80
Figure 9 – Message flow in COS connection – one Connection object, one consumer.....	80
Figure 10 – Message flow in COS connection – multiple consumers .....	81
Figure 11 – Path Reconfiguration in a ring topology .....	93
Figure 12 – CPF2 time synchronization offset clock model.....	94
Figure 13 – CPF2 time synchronization system with offset clock model .....	95
Figure 14 – CPF2 time synchronization group startup sequence .....	97
Figure 15 – Parameter object state transition diagram .....	104
Figure 16 – Example of Find_Next_Object_Instance service .....	130
Figure 17 – Transmission Trigger Timer behavior .....	180
Figure 18 – Inactivity watchdog timer .....	181
Figure 19 – Using tools for configuration.....	181
Figure 20 – Production Inhibit Timer behavior.....	182
Figure 21 – Context of transport services within the connection model.....	189
Figure 22 – Application-to-application view of data transfer .....	189
Figure 23 – Data flow diagram for a link producer .....	190
Figure 24 – Data flow diagram for a link consumer.....	191
Figure 25 – Triggers .....	192
Figure 26 – Binding transport instances to the producer and consumer of a transport connection that does not have a reverse data path .....	193
Figure 27 – Binding transport instances to the producers and consumers of a transport connection that does have a reverse data path .....	193
Figure 28 – Binding transport instances to the producer and consumers of a multipoint connection when the transport connection does not have a reverse data path .....	194
Figure 29 – Binding transport instances to the producers and consumers of a multipoint connection when the transport connection does have reverse data paths .....	194
Table 1 – Valid IANA MIB printer codes for character set selection .....	35
Table 2 – Common elements .....	41
Table 3 – ST language elements.....	42
Table 4 – Type conversion operations.....	43
Table 5 – Values of implementation-dependent parameters .....	45
Table 6 – Extensions to IEC 61131-3:2003 .....	45
Table 7 – Identity object state event matrix.....	61

Table 8 – Static Assembly state event matrix .....	67
Table 9 – Static Assembly instance attribute access .....	68
Table 10 – Dynamic Assembly state event matrix .....	69
Table 11 – Dynamic Assembly instance attribute access.....	69
Table 12 – Message Router object Forward_Open parameters .....	72
Table 13 – Acknowledge Handler object state event matrix.....	76
Table 14 – Producing I/O application object state event matrix .....	77
Table 15 – PTPEnable attribute default values.....	84
Table 16 – Profile identification.....	90
Table 17 – Profile default settings and ranges .....	91
Table 18 – Profile transports.....	91
Table 19 – Default PTP clock settings.....	92
Table 20 – Hand_Set clock quality management.....	92
Table 21 – Path Reconfiguration Signalling message.....	93
Table 22 – Parameter object state event matrix .....	104
Table 23 – Status codes .....	107
Table 24 – Get_Attributes_All service parameters.....	109
Table 25 – Set_Attributes_All service parameters .....	111
Table 26 – Get_Attribute_List service parameters .....	113
Table 27 – Set_Attribute_List service parameters .....	115
Table 28 – Reset service parameters.....	117
Table 29 – Start service parameters .....	119
Table 30 – Stop service parameters.....	120
Table 31 – Create service parameters .....	122
Table 32 – Delete service parameters.....	124
Table 33 – Get_Attribute_Single service parameters.....	125
Table 34 – Set_Attribute_Single service parameters .....	127
Table 35 – Find_Next_Object_Instance service parameters .....	129
Table 36 – NOP service parameters .....	131
Table 37 – Apply_Attributes service parameters .....	132
Table 38 – Save service parameters .....	134
Table 39 – Restore service parameters.....	135
Table 40 – Get_Member service parameters.....	137
Table 41 – Set_Member service parameters .....	139
Table 42 – Insert_Member service parameters.....	141
Table 43 – Remove_Member service parameters.....	143
Table 44 – Group_Sync service parameters.....	144
Table 45 – Add_AckData_Path service parameters.....	146
Table 46 – Remove_AckData_Path service parameters .....	147
Table 47 – Get_Enum_String service parameters .....	148
Table 48 – Symbolic_Translation service parameters.....	150
Table 49 – Flash_LEDs service parameters .....	151
Table 50 – Multiple_Service_Packet service parameters.....	153

Table 51 – CM_Open service parameters .....	163
Table 52 – CM_Close service parameters .....	165
Table 53 – CM_Unconnected_Send service parameters .....	167
Table 54 – CM_Get_Connection_Data service parameters .....	168
Table 55 – CM_Search_Connection_Data service parameters .....	170
Table 56 – CM_Get_Connection_Data service parameters .....	171
Table 57 – I/O Connection object attribute access .....	176
Table 58 – Bridged Connection object attribute access .....	177
Table 59 – Explicit messaging object attribute access .....	178
Table 60 – Connection_Bind service parameters .....	184
Table 61 – Service_Name service parameters .....	185
Table 62 – How production trigger, transport class, and CM_RPI determine when data is produced .....	188
Table 63 – Transport classes .....	199
Table 64 – UCMM_Create service parameters .....	210
Table 65 – UCMM_Delete service parameters .....	211
Table 66 – UCMM_Write service parameters .....	212
Table 67 – UCMM_Abort service parameters .....	213
Table 68 – TR_Write service parameters .....	214
Table 69 – TR_Trigger service parameters .....	215
Table 70 – TR_Packet_arrived service parameters .....	215
Table 71 – TR_Ack_received service parameters .....	216
Table 72 – TR_Verify service parameters .....	216
Table 73 – TR_Status_updated service parameters .....	217
Table 74 – FAL class summary .....	218
Table 75 – FAL services by AR type .....	219

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 5-2: Application layer service definition – Type 2 elements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-5-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- addition of a data type in 5.3.2;
- clarifications of Object management ASE in 6.2.1;
- extensions of General ASE in 6.2.1.2.1;
- extensions/clarifications of Identity ASE in 6.2.1.2.2;
- update of Message Router ASE in 6.2.1.2.4;
- extensions/clarifications of Time Sync ASE in 6.2.1.2.6;
- updates of Parameter ASE in 6.2.1.2.7;
- updates of FAL ASE service specification in 6.2.1.3;
- extensions/clarifications of Connection manager ASE in 6.2.2;
- extensions/clarifications of Connection ASE in 6.2.3;
- extensions/clarifications of Application type in 6.3.1.4.5.
- miscellaneous editorial corrections.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

## **INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –**

### **Part 5-2: Application layer service definition – Type 2 elements**

## **1 Scope**

### **1.1 General**

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 2 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 2 fieldbus application layer in terms of:

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 2 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can