

Australian Standard™

**Insulators—Porcelain and glass, pin and
shackle type—Voltages not exceeding
1000 V a.c.**

This Australian Standard was prepared by Committee EL-010, Overhead Lines. It was approved on behalf of the Council of Standards Australia on 23 May 2005. This Standard was published on 14 June 2005.

The following are represented on Committee EL-010:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Porcelain Insulators Association
Electricity Engineers Association (New Zealand)
Energy Networks Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**Insulators—Porcelain and glass, pin and
shackle type—Voltages not exceeding
1000 V a.c.**

Originated as part of AS C67—1939.
Previous edition AS 3608—1989.
Second edition 2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6773 7

PREFACE

This Standard was reviewed by the Australian members of the Joint Standards Australia/Standards New Zealand committee EL-010, Overhead Lines. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to republish this Australian Standard without technical alterations. There are minor editorial changes and cross-references to referred Standards have been updated.

The Standard applies to porcelain and glass, pin and shackle insulators for voltage up to 1000 V and deals with their dimensions, materials and mechanical performance requirements.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
1 SCOPE AND GENERAL	4
2 GENERAL REQUIREMENTS FOR TESTS.....	5
3 TESTS—TYPE, SAMPLE, AND ROUTINE	6
4 STANDARD CHARACTERISTICS	7
APPENDIX A ITEMS TO BE SPECIFIED BY THE PURCHASER OR SUBJECT TO AGREEMENT BETWEEN THE PURCHASER AND MANUFACTURER	11

STANDARDS AUSTRALIA

Australian Standard

Insulators—Porcelain and glass, pin and shackle type—Voltages not exceeding 1000 V a.c.**1 SCOPE AND GENERAL****1.1 Scope**

This Standard specifies requirements for low voltage pin and shackle insulators in which the insulating material is of porcelain or annealed glass, and which are for use outdoors, at a nominal voltage not greater than 1000 V a.c. and a frequency of not greater than 100 Hz.

NOTE: Appendix A lists information which should be specified by the purchaser of the insulators.

1.2 Referenced documents

The following documents are referred to in this Standard.

AS

- | | |
|--------|---|
| 1154 | Insulator and conductor fittings for overhead power lines |
| 1154.1 | Part 1: Performance, material, general requirements and dimensions |
| 2947 | Insulators—Porcelain and glass for overhead power lines—Voltages greater than 1000 V a.c. |
| 2947.3 | Part 3: Couplings |

1.3 Definitions

For the purpose of this Standard the definitions below apply.

1.3.1 Pin insulator

Insulator consisting of an insulating component intended to be mounted rigidly on a supporting structure by means of a pin passing up inside the insulator. The insulating component may consist of one or more pieces of insulating material permanently connected together with or without a permanently attached pin. The permanent pin insulator has an integral pin.

Separable pin insulators are provided with a threadform in accordance with AS 2947.3. The threadform may be integral or a metal insert cemented into the pin hole.

Unless otherwise stated, the term 'pin insulator' does not include the pin if separable.

1.3.2 Shackle insulator

An insulator consisting of one ceramic or glass part, secured by means of a steel spindle passing through it.

1.3.3 Lot

A group of insulators offered for acceptance from the same manufacturer, of the same design and manufactured under similar conditions of production.

1.3.4 Mechanical failing load

The maximum mechanical load at which failure occurs in an insulator when tested under the prescribed conditions.