

FINAL VERSION

VERSION FINALE



**Low-voltage switchgear and controlgear –
Part 2: Circuit-breakers**

**Appareillage à basse tension –
Partie 2: Disjoncteurs**

CONTENTS

FOREWORD	15
1 General	17
1.1 Scope and object	17
1.2 Normative references	18
2 Terms and definitions	19
3 Classification	23
4 Characteristics of circuit-breakers	24
4.1 Summary of characteristics	24
4.2 Type of circuit-breaker	24
4.3 Rated and limiting values of the main circuit	24
4.3.1 General	24
4.3.2 Rated voltages	24
4.3.3 Currents	25
4.3.4 Rated frequency	25
4.3.5 Rated duty	25
4.3.6 Short-circuit characteristics	26
4.4 Selectivity categories	28
4.5 Control circuits	28
4.5.1 Electrical control circuits	28
4.5.2 Air-supply control circuits (pneumatic or electro-pneumatic)	28
4.6 Auxiliary circuits	28
4.7 Releases	29
4.7.1 Types	29
4.7.2 Characteristics	29
4.7.3 Current setting of over-current releases	29
4.7.4 Tripping time setting of over-current releases	30
4.8 Integral fuses (integrally fused circuit-breakers)	30
5 Product information	30
5.1 Nature of the information	30
5.2 Marking	30
5.3 Instructions for installation, operation and maintenance	32
6 Normal service, mounting and transport conditions	32
7 Constructional and performance requirements	32
7.1 Constructional requirements	32
7.1.1 General	32
7.1.2 Withdrawable circuit-breakers	33
7.1.3 Additional requirements for circuit-breakers suitable for isolation	33
7.1.4 Clearances and creepage distances	33
7.1.5 Requirements for the safety of the operator	33
7.1.6 List of construction breaks	33
7.1.7 Additional requirements for circuit-breakers provided with a neutral pole	34
7.1.8 Digital inputs and outputs for use with programmable logic controllers (PLCs)	34
7.2 Performance requirements	34
7.2.1 Operating conditions	34
7.2.2 Temperature-rise	37

7.2.3	Dielectric properties	38
7.2.4	Ability to make and break under no load, normal load and overload conditions	39
7.2.5	Ability to make and break under short-circuit conditions	40
7.2.6	Vacant	40
7.2.7	Additional requirements for circuit-breakers suitable for isolation	40
7.2.8	Specific requirements for integrally fused circuit-breakers	40
7.2.9	Co-ordination between a circuit-breaker and another short-circuit protective device	40
7.3	Electromagnetic compatibility (EMC)	40
8	Tests	40
8.1	Kind of tests	40
8.1.1	General	40
8.1.2	Type tests	41
8.1.3	Routine tests	41
8.2	Compliance with constructional requirements	41
8.3	Type tests	41
8.3.1	Test sequences	42
8.3.2	General test conditions	49
8.3.3	Test sequence I: General performance characteristics	57
8.3.4	Test sequence II: Rated service short-circuit breaking capacity	66
8.3.5	Test sequence III: Rated ultimate short-circuit breaking capacity	67
8.3.6	Test sequence IV: Rated short-time withstand current	69
8.3.7	Test sequence V: Performance of integrally fused circuit-breakers	70
8.3.8	Test sequence VI: combined test sequence	72
8.3.9	Critical d.c. load current test	73
8.4	Routine tests	74
8.4.1	General	74
8.4.2	Mechanical operation tests	75
8.4.3	Verification of the calibration of overcurrent releases	75
8.4.4	Verification of the operation of undervoltage and shunt releases	76
8.4.5	Additional tests for CBRs	76
8.4.6	Dielectric tests	76
8.4.7	Test for the verification of clearances less than those corresponding to case A of Table 13 of IEC 60947-1:2007	77
8.5	Special tests – Damp heat, salt mist, vibration and shock	77
Annex A (normative)	Co-ordination between a circuit-breaker and another short-circuit protective device associated in the same circuit	79
A.1	General	79
A.2	Scope and object	79
A.3	General requirements for the co-ordination of a circuit-breaker with another SCPD	80
A.3.1	General considerations	80
A.3.2	Take-over current	80
A.3.3	Behaviour of C ₁ in association with another SCPD	80
A.4	Type and characteristics of the associated SCPD	80
A.5	Verification of selectivity	81
A.5.1	General	81
A.5.2	Consideration of selectivity by desk study	81
A.5.3	Selectivity determined by test	82

A.6	Verification of back-up protection	83
A.6.1	Determination of the take-over current.....	83
A.6.2	Verification of back-up protection	83
A.6.3	Tests for verification of back-up protection	83
A.6.4	Results to be obtained.....	84
Annex B (normative)	Circuit-breakers incorporating residual current protection	90
B.1	General.....	90
B.1.1	Preamble	90
B.1.2	Scope and object	90
B.2	Terms and definitions.....	91
B.2.1	Terms and definitions relating to currents flowing from live parts to earth.....	91
B.2.2	Terms and definitions relating to the energization of a CBR	91
B.2.3	Terms and definitions relating to the operation and the functions of a CBR.....	92
B.2.4	Terms and definitions relating to values and ranges of energizing quantities.....	93
B.3	Classification	94
B.3.1	Classification according to the method of operation of the residual current function.....	94
B.3.2	Classification according to the possibility of adjusting the residual operating current.....	94
B.3.3	Classification according to time delay of the residual current function	94
B.3.4	Classification according to behaviour in presence of a d.c. component.....	94
B.4	Characteristics of CBRs concerning their residual current function.....	94
B.4.1	Rated values	94
B.4.2	Preferred and limiting values	95
B.4.3	Value of the rated residual short-circuit making and breaking capacity ($I_{\Delta m}$)	96
B.4.4	Operating characteristics in the case of an earth fault current in the presence or absence of a d.c. component	97
B.5	Marking.....	97
B.6	Normal service, mounting and transport conditions	99
B.7	Design and operating requirements	99
B.7.1	Design requirements	99
B.7.2	Operating requirements.....	99
B.7.3	Electromagnetic compatibility	103
B.8	Tests	103
B.8.1	Test sequences.....	103
B.8.2	Verification of the operating characteristics	106
B.8.3	Verification of dielectric properties.....	108
B.8.4	Verification of the operation of the test device at the limits of rated voltage.....	108
B.8.5	Verification of the limiting value of the non-operating current under over-current conditions.....	109
B.8.6	Verification of the resistance against unwanted tripping due to surge currents resulting from impulse voltages	109
B.8.7	Additional verifications for CBRs of types A and B	110
B.8.8	Additional verifications for CBRs of type B.....	112
B.8.9	Verification of the behaviour of CBRs functionally dependent on line voltage classified under B.3.1.2.1	117

B.8.10	Verification of the behaviour of CBRs functionally dependent on line voltage classified under B.3.1.2.2	117
B.8.11	Verification of the residual short-circuit making and breaking capacity	118
B.8.12	Verification of the effects of environmental conditions.....	119
B.8.13	Verification of electromagnetic compatibility	120
B.8.14	Test for variations or interruptions of voltage and for voltage dips	122
Annex C (normative)	Individual pole short-circuit test sequence	135
C.1	General.....	135
C.2	Test of individual pole short-circuit breaking capacity.....	135
C.3	Verification of dielectric withstand.....	135
C.4	Verification of overload releases.....	135
Annex D (normative)	Additional requirements for circuit-breakers intended for connection of aluminium conductors	136
D.1	General.....	136
D.2	Terms and definitions	136
D.3	Classification	137
D.4	Characteristics	137
D.5	Product information.....	137
D.5.1	Nature of information.....	137
D.5.2	Marking.....	137
D.5.3	Instructions for installation, operation and maintenance	137
D.6	Normal service, mounting and transport conditions	137
D.7	Constructional and performance requirements	138
D.8	Tests	138
D.8.1	General.....	138
D.8.2	Current cycling test	139
D.8.3	Mechanical properties of terminals	141
D.8.4	Test for insertability of unprepared round aluminium conductors having the maximum cross-section	142
Annex E (informative)	Items subject to agreement between manufacturer and user.....	148
Annex F (normative)	Additional tests for circuit-breakers with electronic over-current protection.....	149
F.1	General.....	149
F.2	List of tests	149
F.2.1	General.....	149
F.2.2	Electromagnetic compatibility (EMC) tests	149
F.2.3	Suitability for multiple frequencies	150
F.2.4	Dry heat test	150
F.2.5	Damp heat test.....	150
F.2.6	Temperature variation cycles at a specified rate of change	150
F.3	General test conditions.....	150
F.3.1	General.....	150
F.3.2	Electromagnetic compatibility tests	150
F.4	Immunity tests.....	151
F.4.1	Harmonic currents.....	151
F.4.2	Electrostatic discharges	152
F.4.3	Radiated RF electromagnetic fields	152
F.4.4	Electrical fast transient/burst (EFT/B)	152
F.4.5	Surges	153
F.4.6	Conducted disturbances induced by RF fields (common mode).....	153

F.4.7	Current dips	153
F.5	Emission tests	154
F.5.1	Harmonics	154
F.5.2	Voltage fluctuations	154
F.5.3	Conducted RF disturbances (150 kHz to 30 MHz)	154
F.5.4	Radiated RF disturbances (30 MHz to 1 GHz)	154
F.6	Suitability for multiple frequencies	155
F.6.1	General	155
F.6.2	Test conditions	155
F.6.3	Test procedure	155
F.6.4	Test results	155
F.7	Dry heat test	155
F.7.1	Test procedure	155
F.7.2	Test results	156
F.7.3	Verification of overload releases	156
F.8	Damp heat test	156
F.8.1	Test procedure	156
F.8.2	Verification of overload releases	156
F.9	Temperature variation cycles at a specified rate of change	156
F.9.1	Test conditions	156
F.9.2	Test procedure	156
F.9.3	Test results	157
F.9.4	Verification of overload releases	157
Annex G (normative)	Power loss	171
G.1	General	171
G.2	Test methods	171
G.2.1	General case	171
G.2.2	AC circuit-breakers of rated current not exceeding 400 A	171
G.2.3	DC circuit-breakers	172
G.3	Test procedure	172
Annex H (normative)	Test sequence for circuit-breakers for IT systems	174
H.1	General	174
H.2	Individual pole short-circuit	174
H.3	Verification of dielectric withstand	175
H.4	Verification of overload releases	175
H.5	Marking	175
Annex J (normative)	Electromagnetic compatibility (EMC) – Requirements and test methods for circuit-breakers	176
J.1	General	176
J.2	Immunity	177
J.2.1	General	177
J.2.2	Electrostatic discharges	180
J.2.3	Radiated RF electromagnetic fields	181
J.2.4	Electrical fast transients/bursts (EFT/B)	181
J.2.5	Surges	181
J.2.6	Conducted disturbances induced by RF fields (common mode)	182
J.3	Emission	182
J.3.1	General	182
J.3.2	Conducted RF disturbances (150 kHz to 30 MHz)	183

J.3.3	Radiated RF disturbances (30 MHz to 1 000 MHz)	183
Annex K (informative) Glossary of symbols and graphical representation of characteristics		188
Annex L (normative) Circuit-breakers not fulfilling the requirements for overcurrent protection		197
L.1	General	197
L.2	Terms and definitions	197
L.3	Classification	197
L.4	Rated values	197
L.4.1	Rated current (I_n)	197
L.4.2	Rated conditional short-circuit current (I_{CC})	198
L.5	Product information	198
L.6	Constructional and performance requirements	198
L.7	Tests	198
L.7.1	General	198
L.7.2	Rated conditional short-circuit tests	199
Annex M (normative) Modular residual current devices (without integral current breaking device)		202
M.1	General	202
M.1.1	Preamble	202
M.1.2	Scope and object	202
M.2	Terms and definitions	202
M.2.1	Terms and definitions relating to the energization of an MRCD	202
M.2.2	Terms and definitions relating to the operation and the functions of an MRCD	203
M.3	Classification	203
M.3.1	Classification according to the configuration of the primary conductors	203
M.3.2	Classification according to the method of operation	203
M.3.3	Classification according to the possibility of adjusting the residual operating current	204
M.3.4	Classification according to time delay of the residual current function	204
M.3.5	Classification according to behaviour in presence of a d.c. component	204
M.4	Characteristics of MRCDs	204
M.4.1	General characteristics	204
M.4.2	Characteristics of MRCDs concerning their residual current function	205
M.4.3	Behaviour under short-circuit conditions	205
M.4.4	Preferred and limiting values	206
M.5	Product information	206
M.6	Normal service, mounting and transport conditions	208
M.7	Design and operating requirements	208
M.7.1	Design requirements	208
M.7.2	Operating requirements	208
M.8	Tests	211
M.8.1	General	211
M.8.2	Compliance with constructional requirements	212
M.8.3	Verification of the operating characteristics	212
M.8.4	Verification of dielectric properties	214
M.8.5	Verification of the operation of the test device at the limits of the rated voltage	215

M.8.6	Verification of the limiting value of non-operating current under overcurrent conditions, in the case of a single phase load	215
M.8.7	Verification of the resistance against unwanted tripping due to surge currents resulting from impulse voltages	215
M.8.8	Verification of the behaviour in the case of an earth fault current comprising a d.c. component.....	216
M.8.9	Verification of the behaviour of MRCDs with separate sensing means in the case of a failure of the sensing means connection	219
M.8.10	Verification of temperature-rise of terminal type MRCDs	219
M.8.11	Verification of mechanical and electrical endurance	220
M.8.12	Verification of the behaviour of MRCDs classified under M.3.2.2.1 in the case of failure of the voltage source	220
M.8.13	Verification of the behaviour of MRCDs classified under M.3.2.2.2 in the case of failure of the voltage source	221
M.8.14	Verification of the behaviour of MRCDs under short-circuit conditions	221
M.8.15	Verification of the effects of environmental conditions.....	223
M.8.16	Verification of electromagnetic compatibility	224
Annex N (normative) Electromagnetic compatibility (EMC) – Additional requirements and test methods for devices not covered by Annex B, Annex F and Annex M.....		248
N.1	General.....	248
N.1.1	General.....	248
N.1.2	General test conditions.....	248
N.2	Immunity.....	248
N.2.1	General.....	248
N.2.2	Electrostatic discharges	249
N.2.3	Radiated RF electromagnetic fields	249
N.2.4	Electrical fast transients/bursts (EFT/B).....	249
N.2.5	Surges	250
N.2.6	Conducted disturbances induced by RF fields (common mode).....	250
N.2.7	Voltage dips and interruptions	250
N.3	Emission	250
N.3.1	General.....	250
N.3.2	Conducted RF disturbances (150 kHz to 30 MHz)	251
N.3.3	Radiated RF disturbances (30 MHz to 1 000 MHz).....	251
Annex O (normative) Instantaneous trip circuit-breakers (ICB).....		252
O.1	General.....	252
O.2	Terms and definitions	252
O.3	Rated values	252
O.3.1	General.....	252
O.3.2	Rated current (I_n).....	252
O.3.3	Rated short-circuit making capacity	252
O.3.4	Rated short-circuit breaking capacities	252
O.4	Product information	253
O.5	Constructional and performance requirements	253
O.6	Tests	253
O.6.1	Test sequence of the ICB alone.....	253
O.6.2	ICB associated with a specified protected device (i.e. motor-starter or overload relay).....	254
Annex P (normative) DC circuit-breakers for use in photovoltaic (PV) applications		255
P.1	Field of application	255
P.2	Terms and definitions	255

P.3	Classification	255
P.4	Characteristics of PV circuit-breakers	255
P.5	Product information	256
P.6	Normal service, mounting and transport conditions	256
P.7	Constructional and performance requirements	256
P.7.1	Constructional requirements	256
P.7.2	Performance requirements	256
P.7.3	Electromagnetic compatibility (EMC)	257
P.8	Tests	257
P.8.1	Kind of tests	257
P.8.2	Compliance with constructional requirements	257
P.8.3	Type tests	257
P.8.4	Routine tests	259
P.8.5	Special tests	259
Annex Q	Vacant	260
Annex R (normative)	Circuit-breakers incorporating residual current protection with automatic re-closing functions	261
R.1	General	261
R.1.1	Preamble	261
R.1.2	Field of application	261
R.2	Terms and definitions	262
R.3	Classification	263
R.3.1	According to the method of construction	263
R.3.2	According to the method of automatic reclosing	263
R.4	Characteristics	263
R.4.1	Rated automatic reclosing operating residual current ($I_{\Delta ar}$)	263
R.4.2	Maximum number of consecutive reclosing operations	263
R.5	Marking and instructions	263
R.6	Normal service, mounting and transport conditions	264
R.7	Design and operating requirements	264
R.7.1	Design requirements	264
R.7.2	Operating requirements	265
R.8	Tests	266
R.8.1	General conditions	266
R.8.2	Verification of the non-reclosing after tripping under over-current conditions	266
R.8.3	Verification of the non-reclosing after intentional opening	266
R.8.4	Verification of the automatic reclosing function after tripping on earth fault	267
R.8.5	Verification of mechanical endurance	268
R.8.6	Verification of the isolation function	268
R.8.7	Verification of residual short-circuit making and breaking capacity	269
R.8.8	Verification of the automatic reclosing function after the test sequences of Clause B.8	269
R.8.9	Test items for external type automatic reclosing devices	269
Bibliography	272

Figure 1 – Test arrangement (connecting cables not shown) for short-circuit tests 78

Figure A.1 – Over-current co-ordination between a circuit-breaker and a fuse or back-up protection by a fuse: operating characteristics 85

Figure A.2 – Total selectivity between two circuit-breakers.....	86
Figure A.3 – Back-up protection by a circuit-breaker – Operating characteristics.....	87
Figure A.4 – Example of test circuit for conditional short-circuit breaking capacity tests showing cable connections for a 3-pole circuit-breaker (C_1).....	88
Figure A.5 – Example of test circuit for the verification of selectivity.....	89
Figure B.1 – Test circuit for the verification of the operating characteristic (see B.8.2)	123
Figure B.2 – Test circuit for the verification of the limiting value of the non-operating current under over-current conditions (see B.8.5)	124
Figure B.3 – Test circuit for the verification of the behaviour of CBRs classified under B.3.1.2.2 (see B.8.10)	125
Figure B.4 – Current ring wave 0,5 μ s/100 kHz.....	126
Figure B.5 – Example of a test circuit for the verification of resistance to unwanted tripping	126
Figure B.6 – Surge current wave 8/20 μ s	127
Figure B.7 – Test circuit for the verification of resistance to unwanted tripping in the case of flashover without follow-on current	127
Figure B.8 – Test circuit for the verification of the correct operation of CBRs, in the case of residual pulsating direct currents	128
Figure B.9 – Test circuit for residual pulsating direct current superimposed by a smooth direct current.....	129
Figure B.10 – Test circuit for residual alternating currents superimposed by a smooth direct current.....	130
Figure B.11 – Test circuit for residual pulsating direct currents which can result from rectifying circuits supplied from two phases	131
Figure B.12 – Test circuit for residual pulsating direct currents which can result from rectifying circuits supplied from three phases.....	132
Figure B.13 – Test circuit for residual smooth direct current.....	133
Figure B.14 – Test circuit for composite residual currents, and residual sinusoidal alternating current up to 1 000 Hz.....	134
Figure D.1 – General test arrangement.....	142
Figure D.2 – Mounting of terminals for the current cycling test	143
Figure F.1 – Representation of test current produced by back-to-back thyristors in accordance with F.4.1	158
Figure F.2 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.3 – Two phase poles in series.....	159
Figure F.3 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.3 – Three phase poles in series	159
Figure F.4 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.3 – Three-phase connection	160
Figure F.5 – Test current for the verification of the influence of the current dips and interruptions in accordance with F.4.7.1.....	160
Figure F.6 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Two phase poles in series.....	161
Figure F.7 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three phase poles in series	161
Figure F.8 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three-phase connection	162
Figure F.9 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Two phase poles in series	162

Figure F.10 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three phase poles in series	163
Figure F.11 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three-phase connection.....	163
Figure F.12 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Two phase poles in series	164
Figure F.13 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three phase poles in series.....	164
Figure F.14 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three-phase connection	165
Figure F.15 – Temperature variation cycles at a specified rate of change in accordance with F.9.1	165
Figure F.16 – General test set-up for immunity tests	166
Figure F.17 – Test set-up for the verification of immunity to radiated RF electromagnetic fields	167
Figure F.18 – Test set-up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	167
Figure F.19 – Test set-up for verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	168
Figure F.20 – General test set-up for the verification of immunity to conducted disturbances induced by RF fields (common mode)	168
Figure F.21 – Arrangement of connections for the verification of immunity to conducted disturbances induced by RF fields – Two phase poles in series configuration.....	169
Figure F.22 – Arrangement of connections for the verification of immunity to conducted disturbances induced by RF fields – Three phase poles in series configuration	169
Figure F.23 – Arrangement of connections for the verification of immunity to conducted disturbances induced by RF fields – Three-phase configuration	170
Figure G.1 – Example of power loss measurement according to G.2.1	172
Figure G.2 – Example of power loss measurement according to G.2.2 and G.2.3	173
Figure J.1 – EUT mounted in a metallic enclosure	184
Figure J.2 – Test set up for the measurement of radiated RF emissions.....	185
Figure J.3 – Test set up for the verification of immunity to electrostatic discharges	186
Figure J.4 – Test set up for the verification of immunity to radiated RF electromagnetic fields.....	186
Figure J.5 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	187
Figure J.6 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	187
Figure K.1 – Relationship between symbols and tripping characteristics.....	190
Figure K.2 – Template for characteristics of cut-off current versus prospective current from 1 kA to 200 kA	191
Figure K.3 – Template for characteristics of cut-off current versus prospective current from 0,01 kA to 200 kA.....	192
Figure K.4 – Template for characteristics of let-through energy versus prospective current from 1 kA to 200 kA.....	193
Figure K.5 – Template for characteristics of let-through energy versus prospective current from 0,01 kA to 200 kA.....	194
Figure K.6 – Example of the use of template to Figure K.2.....	195
Figure K.7 – Example of the use of template to Figure K.4.....	196

Figure M.1 – Test circuits for the verification of operation in the case of a steady increase of residual current	225
Figure M.2 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (with current breaking device).....	226
Figure M.3 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (without current breaking device)	227
Figure M.4 – Test circuits for the verification of the limiting value of non-operating current under overcurrent conditions	228
Figure M.5 – Test circuits for the verification of the resistance to unwanted tripping in the case of loading of the network capacitance	229
Figure M.6 – Test circuit for the verification of the resistance to unwanted tripping in the case of flashover without follow-on current	230
Figure M.7 – Test circuits for the verification of operation in the case of a continuous rise of a residual pulsating direct current	231
Figure M.8 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (without current-breaking device).....	232
Figure M.9 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (with current-breaking device)	233
Figure M.10 – Test circuits for the verification of operation in the case of a residual pulsating direct current superimposed by a smooth direct current	234
Figure M.11 – Test circuits for the verification of operation in the case of a slowly rising residual smooth direct current	235
Figure M.12 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (without current-breaking device)	236
Figure M.13 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (with current-breaking device).....	237
Figure M.14 – Test circuits for the verification of the correct operation in the case of residual direct currents which can result from rectifying circuits supplied from three phases	238
Figure M.15 – Test circuits for the verification of the correct operation in the case of residual direct currents which can result from rectifying circuits supplied from two phases	239
Figure M.16 – Test circuits for the verification of correct operation in the case of composite residual currents and residual sinusoidal alternating current up to 1 000 Hz	240
Figure M.17 – Test circuits for the verification of the correct operation in the case of a residual alternating current superimposed on a smooth direct current	241
Figure M.18 – Test circuit for the verification of the behaviour of MRCDs with separate sensing means in the case of a failure of the connection of the sensing means.....	242
Figure M.19 – Test circuit for the verification of the behaviour of MRCD with separate sensing means under short-circuit conditions.....	243
Figure M.20 – Test circuit for the verification of the behaviour of MRCD with integral sensing means under short-circuit conditions.....	244
Figure M.21 – Test circuit for the verification of the behaviour of terminal-type MRCDs under short-circuit conditions.....	245
Figure M.22 – Verification of immunity to radiated RF electromagnetic fields – Test set-up for MRCDs with separate sensing means (in addition to the test of Annex B).....	246
Figure M.23 – Verification of immunity to electrical fast transients/bursts (EFT/B) on the sensing means connection of an MRCD with separate sensing means (in addition to the test of Annex B)	246
Figure M.24 – Verification of immunity to conducted disturbances induced by RF fields – Test setup for MRCD with separate sensing means (in addition to the test of Annex B).....	247
Figure R.1 – Test circuit for the verification of the automatic reclosing functions	271

Table 1 (void).....	27
Table 2 – Ratio n between short-circuit making capacity and short-circuit breaking capacity and related power factor (for a.c. circuit-breakers)	27
Table 3 – Minimum values of rated short-time withstand current	28
Table 4 (void).....	28
Table 5 – Preferred values of the rated control supply voltage, if different from that of the main circuit	28
Table 6 – Characteristics of the opening operation of inverse time-delay over-current opening releases at the reference temperature	37
Table 7 – Temperature-rise limits for terminals and accessible parts	38
Table 8 – Number of operating cycles.....	39
Table 9 – Overall schema of test sequences ^a	44
Table 9a – Applicability of test sequences according to the relationship between I_{CS} , I_{CU} and I_{CW} ^a	45
Table 9b – Applicability of tests or test sequences to 1, 2 and 4-pole circuit-breakers according to the alternative programme 1 of 8.3.1.4.....	47
Table 9c – Applicability of tests or test sequences to 1, 2 and 3-pole circuit-breakers according to the alternative programme 2 of 8.3.1.4.....	48
Table 10 – Number of samples for test (1 of 2).....	51
Table 11 – Values of power factors and time constants corresponding to test currents.....	53
Table 12 – Test circuit characteristics for overload performance	65
Table 13 – Product information.....	31
Table B.1 – Operating characteristic in the case of sinusoidal residual current for non-time-delay type.....	96
Table B.2 – Operating characteristics in the case of sinusoidal residual currents, for time-delay type having a limiting non-actuating time of 0,06 s	96
Table B.3 – Product information	98
Table B.4 – Requirements for CBRs functionally dependent on line voltage.....	103
Table B.5 – Additional test sequences	106
Table B.6 – Tripping current range for CBRs in the case of an earth fault comprising a d.c. component	111
Table B.7 – Composite test current definition and starting current value.....	113
Table B.8 – Operating current range for composite residual current	113
Table B.9 – Operating limits for residual sinusoidal alternating currents up to 1 000 Hz.....	114
Table D.1 – List of tests for terminal connections ^a with aluminium cables	138
Table D.2 – Conductor length for the current cycling test as per conductor cross-section	143
Table D.3 – Equalizer dimensions	143
Table D.4 – Starting test current for the current cycling test	144
Table D.5 – Example of stability factor calculation.....	144
Table D.6 – Test values for flexion and pull-out test for cables.....	145
Table D.7 – Test aluminium cables for test currents up to 800 A ^{a,d}	146
Table D.8 – Test aluminium bars for test currents above 400 A ^g and up to 3 150 A ^{a, f}	147
Table F.1 – Test parameters for current dips and interruptions	154
Table H.1 – Product information	175
Table J.1 – EMC – Immunity tests	178
Table J.2 – Reference data for immunity test specifications	180

Table J.3 – EMC – Emission tests	183
Table J.4 – Reference data for emission test specifications	183
Table L.1 – Product information.....	198
Table M.1 – Product information.....	207
Table M.2 – Requirements for MRCs with voltage source	210
Table M.3 – Test sequences	211
Table O.1 – Product information	253
Table P.1 – Rated impulse withstand levels for PV circuit-breakers.....	255
Table P.2 – Number of operating cycles	257
Table P.3 – Product information	256
Table R.2 – Product information	264
Table R.1 – Test sequences for external type automatic re-closing devices.....	270

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 2: Circuit-breakers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 60947-2 bears the edition number 5.1. It consists of the fifth edition (2016-06) [documents 121A/71/FDIS and 121A/83/RVD], its corrigendum (2016-11) and its amendment 1 (2019-07) [documents 121A/286/FDIS and 121A/302/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60947-2 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low-voltage.

This fifth edition constitutes a technical revision.

This edition includes the following significant additions with respect to the previous edition:

- tests for verification of selectivity in Annex A (see A.5.3);
- critical load current tests for d.c. circuit-breakers (see 8.3.9);
- new Annex P for circuit-breakers for use in photovoltaic applications;
- new Annex R for residual-current circuit-breakers with automatic reclosing functions.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This International Standard is to be used in conjunction with IEC 60947-1:2007 and its Amendment 1:2010 and Amendment 2:2014.

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this standard, where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1 and its amendments when applicable, for example, 1.2.3 of IEC 60947-1:2007, Table 4 of IEC 60947-1:2007/AMD1:2010, or Annex A of IEC 60947-1:2007/AMD1:2010/AMD2:2014.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 2: Circuit-breakers

1 General

1.1 Scope and object

This part of IEC 60947 series applies to circuit-breakers, intended to be installed and operated by instructed or skilled persons, the main contacts of which are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.; it also contains additional requirements for integrally fused circuit-breakers.

Circuit-breakers rated above 1 000 V a.c. but not exceeding 1 500 V a.c. may also be tested to this standard.

It applies whatever the rated currents, the method of construction or the proposed applications of the circuit-breakers may be.

The requirements for circuit-breakers which are also intended to provide earth leakage protection are contained in Annex B.

The additional requirements for circuit-breakers with electronic over-current protection are contained in Annex F.

The additional requirements for circuit-breakers for IT systems are contained in Annex H.

The requirements and test methods for electromagnetic compatibility of circuit-breakers are contained in Annex J.

The requirements for circuit-breakers not fulfilling the requirements for over-current protection are contained in Annex L.

The requirements for modular residual current devices (without integral current breaking device) are contained in Annex M.

The requirements and test methods for electromagnetic compatibility of circuit-breaker auxiliaries are contained in Annex N.

The requirements and test methods for d.c. circuit-breakers for use in photovoltaic (PV) applications are contained in Annex P.

The requirements and test methods for circuit-breakers incorporating residual current protection with automatic reclosing functions are contained in Annex R.

Supplementary requirements for circuit-breakers used as direct-on-line starters are given in IEC 60947-4-1, applicable to low-voltage contactors and starters.

The requirements for circuit-breakers for the protection of wiring installations in buildings and similar applications, and designed for use by uninstructed persons, are contained in IEC 60898.