

# FINAL VERSION

# VERSION FINALE



---

**Automatic electrical controls –  
Part 1: General requirements**

**Dispositifs de commande électrique automatiques –  
Partie 1: Exigences générales**

## CONTENTS

FOREWORD .....	7
1 Scope and normative references .....	10
2 Terms and definitions .....	15
3 General requirements .....	37
4 General notes on tests .....	38
5 Rating.....	41
6 Classification .....	41
7 Information .....	49
8 Protection against electric shock .....	58
9 Provision for protective earthing .....	61
10 Terminals and terminations.....	64
11 Constructional requirements .....	72
12 Moisture and dust resistance .....	91
13 Electric strength and insulation resistance .....	93
14 Heating.....	96
15 Manufacturing deviation and drift.....	102
16 Environmental stress .....	103
17 Endurance .....	104
18 Mechanical strength .....	114
19 Threaded parts and connections.....	121
20 Creepage distances, clearances and distances through solid insulation.....	124
21 Resistance to heat, fire and tracking.....	133
22 Resistance to corrosion .....	135
23 Electromagnetic compatibility (EMC) requirements – Emission .....	136
24 Components .....	137
25 Normal operation .....	139
26 Electromagnetic compatibility (EMC) requirements – Immunity .....	139
27 Abnormal operation .....	139
28 Guidance on the use of electronic disconnection .....	142
Annex A (normative) Indelibility of markings.....	162
Annex B (normative) Measurement of creepage distances and clearances in air .....	164
Annex C (normative) Cotton used for mercury switch test (not applicable in the countries members of CENELEC) .....	169
Annex D (informative) Heat, fire and tracking .....	170
Annex E (normative) Circuit for measuring leakage current.....	171
Annex F (informative) Fire hazard testing.....	172
Annex G (normative) Heat and fire resistance tests.....	173
Annex H (normative) Requirements for electronic controls .....	175
Annex J (normative) Requirements for thermistor elements and controls using thermistors.....	241
Annex K (informative) Nominal voltages of supply systems for different modes of overvoltage control .....	259

Annex L (normative) Overvoltage categories.....	261
Annex M (informative) Typical usage .....	262
Annex N (normative) Pollution degrees .....	263
Annex P (normative) Printed circuit board coating performance test.....	264
Annex Q (normative) Printed circuit board coating performance test .....	266
Annex R (informative) Explanatory notes for surge immunity test.....	269
Annex S (informative) Guidance for applying Clause 20 .....	274
Annex T (normative) Requirements for SELV and PELV.....	276
Annex U (normative) Requirements for relays when used as controls in IEC 60335 appliances .....	279
Annex V (normative) Requirements for controls powered by secondary batteries (rechargeable) .....	282
Bibliography.....	284
Figure 1 – Test pin.....	142
Figure 2 – Standard test finger.....	143
Figure 3 – Test nail .....	144
Figure 4 – Impact test for free-standing controls .....	145
Figure 5 – Tumbling barrel .....	145
Figure 6 – Ball-pressure apparatus .....	146
Figure 7 – Void .....	146
Figure 8 – Apparatus for testing durability of markings on rating labels .....	146
Figure 9 – Apparatus for flexing test .....	147
Figure 10 – Screw terminals and stud terminals .....	148
Figure 11 – Pillar terminals .....	150
Figure 12 – Mantle terminals.....	151
Figure 13 – Saddle and lug terminals .....	152
Figure 14 – Tabs.....	153
Figure 15 – Tabs for non-reversible connectors .....	154
Figure 16 – Receptacles .....	155
Figure 17 – Measurement of creepage distance and clearance .....	156
Figures 18 to 24 Void.....	157
Figure 25 – Diagram for leakage current measurement at operating temperature for single-phase connection of class II controls .....	157
Figure 26 – Diagram for leakage current measurement at operating temperature for single-phase connection of controls other than class II .....	158
Figure 27 – Diagram for leakage current measurement at operating temperature for three-phase connection of class II controls .....	159
Figure 28 – Diagram for leakage current measurement at operating temperature for three-phase connection of controls other than class II.....	160
Figure 29 – Diagram for leakage current measurement at operating temperature for single-phase connection of controls other than class II .....	160
Figure 30 – Diagram for leakage current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II .....	161
Figure B.1 – Narrow groove .....	165

Figure B.2 – Wide groove .....	165
Figure B.3 – V-shaped groove.....	165
Figure B.4 – Rib.....	166
Figure B.5 – Uncemented joint with narrow groove .....	166
Figure B.6 – Uncemented joint with wide groove .....	166
Figure B.7 – Uncemented joint with narrow and wide grooves .....	167
Figure B.8 – Diverging side walls .....	167
Figure B.9 – Narrow recess.....	168
Figure B.10 – Wide recess .....	168
Figure B.11 – Conductive floating part .....	168
Figure E.1 – Circuit for measuring leakage currents .....	171
Figure H.1 – V-Model for the software life cycle .....	201
Figure H.2 – Voltage variation test .....	218
Figure H.3 – Ring wave characteristics (open-circuit voltage) .....	223
Figure H.4 – Schematic of a ring wave generator 0,5 μs /100 kHz.....	223
Figure H.5 – Example of an electronic circuit with low power points .....	228
Figure J.1 – Test circuit for inrush-current limiting thermistor endurance test .....	257
Figure P.1 – Test sample .....	265
Figure Q.1 – Example of type 1 protection.....	267
Figure Q.2 – Example of type 2 protection.....	268
Figure R.1 – Example of surge protection by shielding in buildings with common earth reference systems.....	272
Figure R.2 – Example of secondary surge protection in buildings with separate common earth reference systems .....	272
Figure R.3 – Example of primary and secondary surge protection of indoor/outdoor equipment.....	273
Figure S.1 – Guidance flowchart for application of requirements of Clause 20 .....	274
Table 1 (7.2 of edition 3) – Required information and methods of providing information) .....	52
Table 2 (9.3.2 of edition 3) – Quick connect terminal dimensions (Canada and USA).....	63
Table 3 (10.1.4 of edition 3) – Minimum cross-sectional area of conductors .....	65
Table 4 (10.1.8 of edition 3) – Terminal conductors.....	67
Table 5 (10.1.9 of edition 3) – Conductor pull test values .....	68
Table 6 (10.2.1 of edition 3) – Nominal cross-sectional areas of conductors .....	70
Table 7 (10.2.4.2 of edition 3) – Material and plating for tabs .....	71
Table 8 (10.2.4.3 of edition 3) – Axial force values for tab insertion and withdrawal .....	71
Table 9 (11.7.2 of edition 3) – Pull and torque values .....	83
Table 10 (11.8.2 of edition 3) – Minimum cord conductor sizes .....	84
Table 11 (13.1 of edition 3) – Minimum insulation resistance .....	93
Table 12 (13.2 of edition 3) – Insulation or disconnection test voltages <sup>a</sup> .....	94
Table 13 (14.1 of edition 3) – Maximum heating temperatures .....	99
Table 14 (17.2.1 of edition 3) – Electrical conditions for the overvoltage test (this table applies in all countries except Canada, and the USA) .....	106

Table 15 (17.2.2 of edition 3) – Electrical conditions for the overload tests of 17.7 and 17.10 (this table applies in Canada, USA, and all countries which use an overload test) .....	107
Table 16 (17.2.3 of edition 3) – Electrical conditions for the endurance tests of 17.8, 17.9, 17.11, 17.12 and 17.13 (this table applies in Canada, USA, and all countries which use an overload test) .....	109
Table 17 (18.4.1 of edition 3) – Minimum thickness of sheet metal for enclosures made of carbon steel or stainless steel .....	117
Table 18 (18.4.2 of edition 3) – Minimum thickness of sheet metal for enclosures of aluminium, copper or brass .....	118
Table 19 (18.7 of edition 3) – Pull-cord force test values .....	120
Table 20 (19.1 of edition 3) – Threaded parts torque test values .....	122
Table 21 (20.1 of edition 3) – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1) .....	125
Table 22 (20.2 of edition 3) – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2) .....	126
Table 23 (20.3 of edition 3) – Minimum creepage distances for basic insulation .....	130
Table 24 (20.4 of edition 3) – Minimum creepage distances for functional insulation .....	131
Table 25 (21.4 of edition 3) – Mercury switch short-circuit conditions .....	135
Table 26 (27.2.3 of edition 3) – Maximum winding temperature (for test of mechanical blocked output conditions) .....	140
Table B.1 – Value of $X$ .....	164
Table H.1 (H.11.12.7 of edition 3) – Acceptable measures to address fault/errors <sup>a</sup> .....	194
Table H.2 – Semi-formal methods .....	201
Table H.3 – Software architecture specification .....	202
Table H.4 – Module design specification .....	203
Table H.5 – Design and coding standards .....	203
Table H.6 – Software module testing .....	204
Table H.7 – Software integration testing .....	205
Table H.8 – Software safety validation .....	205
Table H.9 (H.11.12.6 of edition 3) – Combinations of analytical measures during hardware development .....	206
Table H.10 – Data exchange .....	207
Table H.11 – Examples of defences against unauthorised access and transmission failure modes .....	208
Table H.12 (H.23 of edition 3) – Emission .....	214
Table H.13 (H.26.2.1 of edition 3) – Applicable test levels .....	215
Table H.14 – Voltage dips, short interruptions and voltage variations .....	217
Table H.15 (H.26.5.4.2 of edition 3) – Test values for voltage variations .....	218
Table H.16 (H.26.8.2 of edition 3) – Test voltages for test level 2 (depending on the installation class conditions) .....	220
Table H.17 – Test level for electrical fast transient burst test .....	221
Table H.18 (H.26.10.4 of edition 3) – Peak voltages .....	222
Table H.19 (H.26.12.2.1 of edition 3) – Test levels for conducted disturbances on mains and I/O lines .....	224
Table H.20 (H.26.12.3.1 of edition 3) – Test level for immunity to radiated electromagnetic fields .....	225
Table H.21 – Increased test level for radiated immunity (ISM, GSM, DECT bands) .....	225

Table H.22 (H.26.13.2 of edition 3) – Test level for supply frequency variations .....	226
Table H.23 (H.26.14.2 of edition 3) – Test level for continuous fields .....	227
Table H.24 (H.27.1 of edition 3) – Electrical/electronic component fault modes table .....	231
Table J.1 – Maximum current.....	243
Table J.2 (J.7, 7.2 of edition 3) – Normal operating conditions .....	244
Table J.3 – Samples for the test (clause reference) .....	245
Table J.4 – Electrical and thermal ratings of a thermistor .....	246
Table J.5 – Additional items to Table 1 .....	248
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors .....	250
Table J.7 – Classes for PTC sensing thermistors .....	251
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors .....	252
Table J.9 – Classes for NTC sensing thermistors .....	252
Table J.10 – Number of cycles for endurance test.....	255
Table J.11 – Ageing test temperature.....	256
Table J.12 – Number of cycles for endurance test.....	257
Table K.1 – Inherent control or equivalent protective control .....	259
Table K.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1 .....	260
Table M.1 – Typical usage .....	262
Table P.1 – Environmental cycling conditions .....	264
Table Q.1 – IEC 60664-3 test levels or conditions.....	266
Table S.1 – Example A – Using Annex S guidance for applying Clause 20.....	275
Table S.2 – Example B – Using Annex S guidance for applying Clause 20.....	275

INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**AUTOMATIC ELECTRICAL CONTROLS –**

**Part 1: General requirements**

**FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**DISCLAIMER**

**This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.**

**This Consolidated version of IEC 60730-1 bears the edition number 5.2. It consists of the fifth edition (2013-11) [documents 72/899/FDIS and 72/928/RVD] and its corrigendum 1 (2014-09), its amendment 1 (2015-12) [documents 72/1017/FDIS and 72/1026/RVD] and its amendment 2 (2020-04) [documents 72/1226/FDIS and 72/1237/RVD]. The technical content is identical to the base edition and its amendments.**

**This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.**

International Standard IEC 60730-1 has been prepared by IEC technical committee 72: Automatic electrical controls.

This edition constitutes a technical revision. The major changes with respect to the previous edition are as follows.

- modification of the title and scope;
- revisions to Clause H.26 based on changes in technology, applications, and to improve consistency and layout;
- modification to Table H.12 to align with CISPR 22;
- revisions to Annex J to correlate the fault modes of thermistors and to exempt thermistors used in conjunction with type 1 controls in SELV low power circuits from the tests specified in Annex J;
- new requirements covering battery-powered controls, and the use of batteries in controls;
- revision addressing the exclusion of relay faults;
- new/updated requirements in Clause 24, for switch mode power supplies;
- revisions covering the allowance of screwless-type clamping units complying with IEC 60999-1;
- new requirements addressing remotely actuated control functions;
- addition of a new/updated leakage current diagram to align the Annex E diagram with the diagram in IEC 60990;
- updated requirements for temperature sensing controls.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

In the development of a fully international standard to cover automatic controls for household and similar use, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The “in some countries” notes regarding differing national practices are contained in the following subclauses:

2.1.5	11.11.1.2	17.10.4
2.7.2	11.11.1.3	17.12.5
2.7.3	11.11.1.4	18.1.6
2.14.2	12.1.6	18.1.6.1
4.2.1	12.3	18.1.6.2
6.6.1	Table 12 (13.2.1), footnote a	18.1.6.3
Table 1 (7.2), footnote d	13.3.4	18.4
7.4.3	14.4	19.2.4.1
7.4.3.2	Table 13 (14.7.4), footnote f	19.2.5.1
8.1.1.1	15.1	21.1
8.4	16.2.1	21.4
9.3.2	17.1.3.1	27.2.3.1
9.3.4	17.2.2	Annex C
9.5.2	17.2.3	Annex D
Table 3 (10.1.4), footnote b	17.2.3.1	H.26.10
10.1.4.1	Table 14 (17.2.5)	Table H.18 (H.26.10.4)
10.1.14	Table 15 (17.2.5)	H.27.1.1.3
10.1.16	Table 16 (17.2.5)	Table K.1, footnote b
10.1.16.1	17.5.1	Table K.2, footnote b

Table 6 (10.2.1), footnote b	17.7.7	T.3.2
11.5	17.8.4.1	
Table 10 (11.8.2), footnote b	17.10	

It is envisaged that in the next edition of this standard it will be found possible to remove those differences that are covered by new IEC standards now being prepared by other technical committees.

This part 1 is to be used in conjunction with the appropriate part 2 for a particular type of control, or for controls for particular applications. This part 1 may also be applied, so far as reasonable, to controls not mentioned in a part 2, and to controls designed on new principles, in which cases additional requirements may be considered to be necessary.

Where, for a particular clause or subclause, the text of part 2 indicates:

*Addition:* the part 1 text applies with the additional requirement indicated in a part 2;

*Modification:* the part 1 text applies with a minor change as indicated in a part 2;

*Replacement:* the part 2 text contains a change which replaces the part 1 text in its entirety.

Where no change is necessary, the part 2 indicates that the relevant clause or subclause applies.

NOTE In this standard the following print types are used:

- Requirements proper: in roman type;
- *Test specifications: in italic type;*
- Explanatory matter: in smaller roman type;
- Defined terms: **bold type**.

Some table titles contain reference in brackets to table numbers in IEC 60730-1, edition 3 for ease of correlation between parts 2 and the Part 1.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

# AUTOMATIC ELECTRICAL CONTROLS –

## Part 1: General requirements

### 1 Scope and normative references

#### 1.1 Scope

In general, this part of IEC 60730 applies to automatic **electrical controls** for use in, on, or in association with equipment for household and similar use. The equipment may use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this standard the word "equipment" means "appliance and equipment."

EXAMPLE 1 **Controls** for appliances within the scope of IEC 60335.

This International Standard is applicable to **controls** for building automation within the scope of ISO 16484.

This standard also applies to automatic **electrical controls** for equipment that may be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

EXAMPLE 2 **Controls** for commercial catering, heating and air-conditioning equipment.

This standard is also applicable to individual **controls** utilized as part of a **control** system or **controls** which are mechanically integral with multifunctional **controls** having non-electrical outputs.

EXAMPLE 3 Independently mounted water valves, **controls** in smart grid systems and **controls** for building automation systems within the scope of ISO 16484-2.

This standard is also applicable to relays when used as **controls** for IEC 60335 appliances. Additional requirements for the safety and **operating values** of relays when used as **controls** for IEC 60335 appliances are contained in Annex U.

NOTE 2 These requirements are referred to in the scope of IEC 61810-1.

NOTE 3 This standard is intended to be used for the testing of any stand-alone relay which is intended to be used as a **control** of an appliance according to IEC 60335-1. It is not intended to be used for any other stand-alone relay, or to replace the IEC 61810 series of standards.

This standard does not apply to automatic **electrical controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard.

This standard applies to **controls** powered by primary or secondary batteries, requirements for which are contained within the standard, including Annex V.

**1.1.1** This International Standard applies to the inherent safety, to the **operating values**, **operating times**, and **operating sequences** where such are associated with equipment safety, and to the testing of automatic **electrical control** devices used in, or in association with, equipment.

This standard applies to **controls** using **thermistors**, see also Annex J.