

FINAL VERSION

VERSION FINALE

Thermal-links – Requirements and application guide

Protecteurs thermiques – Exigences et guide d'application



CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 General requirements	10
5 General notes on tests	11
6 Classification	13
6.1 Electrical conditions	13
6.2 Thermal conditions	14
6.3 Resistance to tracking	14
7 Marking	14
8 Documentation	15
9 Constructional requirements	15
9.1 General	15
9.2 Lead secureness tests	16
9.2.1 General	16
9.2.2 Tensile test	16
9.2.3 Thrust test	17
9.2.4 Bending/twist test	17
9.3 Contacts used for the current path	18
9.4 Accessible mounting brackets or metal parts	18
9.5 Insulating materials	18
9.6 Resistance to tracking	18
9.7 Creepage distances and clearances	18
9.8 Temperature and humidity cycle conditioning	19
9.9 Terminals and terminations	19
10 Electrical requirements	19
10.1 Dielectric strength	19
10.2 Insulation resistance	20
10.3 Interrupting current	21
10.3.1 General	21
10.3.2 Specific conditions	21
10.4 Transient overload current	22
10.5 Limited short-circuit test	23
10.5.1 General	23
10.5.2 Test method	23
10.5.3 Fuse size (rating)	23
10.5.4 Compliance	24
11 Temperature tests	24
11.1 General	24
11.2 Holding temperature, T_h	24
11.3 Rated functioning temperature, T_f	25
11.4 Maximum temperature limit, T_m	25

11.5	Ageing	25
12	Resistance to rusting	26
13	Manufacturer's validation programme	26
	Annex A (normative) Application guide.....	28
	Annex B (normative) Alternative ageing test for thermal-links with T_h greater than 250 °C for use in electric irons	29
	Annex C (normative) Conductive heat ageing test.....	30
C.1	Conductive heat ageing test.....	30
C.2	Method	30
C.3	Ageing	31
C.4	Results	32
C.5	Dielectric strength test	32
C.6	Test oven.....	32
	Annex D (informative) Extended holding temperature evaluation.....	34
D.1	Extended holding temperature conditioning test	34
D.2	Load current interrupt test.....	34
	Annex E (normative) Seal ageing test	36
	Annex F (normative) Identification requirements	38
	Annex G (normative) Indelibility of markings	39
	Annex H (normative) Requirements for thermal-link packaged assemblies	40
	Bibliography.....	43
	Figure 1 – Bending/twist test.....	17
	Figure C.1 – Typical test fixture assembly.....	32
	Figure C.2 – Typical thermal-link test oven	33
	Figure D.1 – Typical terminal block support test fixture	35
	Figure E.1 – Conditioning time versus oven temperature for proposed temperature index.....	37
	Figure G.1 – Apparatus for testing durability of markings	39
	Table 1 – Test schedule.....	13
	Table 2 – Strength of leads and terminal parts – Minimum required tensile and thrust test forces.....	17
	Table 3 – Creepage distances and clearances (absolute minimum values)	19
	Table 4 – Test voltages for dielectric strength.....	20
	Table 5 – Test current for interrupting test	21
	Table 6 – Limited short-circuit test capacity	23
	Table H.1 – Push and pull force	41
	Table H.2 – Minimum nominal cross-sectional area of conductor	42

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**THERMAL-LINKS –
REQUIREMENTS AND APPLICATION GUIDE****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60691 edition 4.1 contains the fourth edition (2015-10) [documents 32C/512/FDIS and 32C/515/RVD] and its corrigendum (2016-08), and its amendment 1 (2019-01) [documents 32C/548/FDIS and 32C/559/RVD].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60691 has been prepared by subcommittee 32C: Miniature fuses, of IEC technical committee 32: Fuses.

This fourth edition constitutes a technical revision.

This fourth edition includes the following significant technical changes with respect to the previous edition:

- a) requirements for thermal-link packaged assemblies;
- b) renew the requirements and definitions for T_h -test;
- c) change starting temperature for interrupt current test;
- d) clarify requirements for marking (packing label);
- e) minimum Proof Tracking Index 175 instead 120.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The basis for this standard is the harmonization of the USA national standard, UL 1020, fifth edition (withdrawn 2003), and IEC 60691:1993, together with its Amendment 1:1995 and Amendment 2:2000.

The following differing practices of a less permanent nature exist in the country indicated below:

- Annex C is required to be declared in the USA;
- Annex E is required in the USA, if applicable;
- Annex F is required to be declared in the USA.

In this standard, the following type is used:

- *compliance statements: in italic type.*

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Thermal-links, defined as non-resettable devices functioning once only without refunctioning, are widely applied for the thermal protection of equipment in which, under fault (abnormal) conditions, one or more parts may reach hazardous temperatures.

As these devices have several aspects in common with miniature fuse-links and are used for obtaining a comparable degree of protection, this standard has endeavoured to lay down a number of basic requirements for such devices.

THERMAL-LINKS – REQUIREMENTS AND APPLICATION GUIDE

1 Scope

This International Standard is applicable to thermal-links intended for incorporation in electrical appliances, electronic equipment and component parts thereof, normally intended for use indoors, in order to protect them against excessive temperatures under abnormal conditions.

NOTE 1 The equipment is not designed to generate heat.

NOTE 2 The effectiveness of the protection against excessive temperatures logically depends upon the position and method of mounting of the thermal-link, as well as upon the current which it is carrying.

This standard may be applicable to thermal-links for use under conditions other than indoors, provided that the climatic and other circumstances in the immediate surroundings of such thermal-links are comparable with those in this standard.

This standard may be applicable to thermal-links in their simplest forms (e.g. melting strips or wires), provided that molten materials expelled during function cannot adversely interfere with the safe use of the equipment, especially in the case of hand-held or portable equipment, irrespective of its position.

Annex H of this standard is applicable to thermal-link packaged assemblies where the thermal-link(s) has already been approved to this standard but packaged in a metallic or non-metallic housing and provided with terminals/wiring leads.

This standard is applicable to thermal-links with a rated voltage not exceeding 690 V a.c. or d.c. and a rated current not exceeding 63 A.

The objectives of this standard are:

- a) to establish uniform requirements for thermal-links,
- b) to define methods of test,
- c) to provide useful information for the application of thermal-links in equipment.

This standard is not applicable to thermal-links used under extreme conditions such as corrosive or explosive atmospheres.

This standard is not applicable to thermal-links to be used in circuits on a.c. with a frequency lower than 45 Hz or higher than 62 Hz.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*