

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-2: Application layer service definition – Type 2 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-2: Définition des services de la couche application – Éléments de type 2**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-2: Application layer service definition – Type 2 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-2: Définition des services de la couche application – Eléments de type 2**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-9264-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications	10
1.3 Conformance	10
2 Normative references	10
3 Terms, definitions, symbols, abbreviated terms and conventions	12
3.1 ISO/IEC 7498-1 terms.....	12
3.2 ISO/IEC 8822 terms.....	13
3.3 ISO/IEC 9545 terms.....	13
3.4 ISO/IEC 8824-1 terms.....	13
3.5 Type 2 fieldbus data-link layer terms.....	13
3.6 Type 2 fieldbus application-layer specific definitions	13
3.7 Type 2 abbreviated terms and symbols	21
3.8 Conventions.....	22
3.8.1 Overview	22
3.8.2 General conventions.....	23
3.8.3 Conventions for class definitions	23
3.8.4 Conventions for service definitions	24
4 Common concepts.....	25
5 Data type ASE.....	25
5.1 General.....	25
5.2 Formal definition of data type objects.....	25
5.3 FAL defined data types	26
5.3.1 Fixed length types	26
5.3.2 String types	31
5.3.3 Structure types	32
5.4 Data type ASE service specification.....	36
6 Communication model specification.....	36
6.1 Concepts	36
6.1.1 General	36
6.1.2 General concepts	36
6.1.3 Relationships between ASEs	37
6.1.4 Naming and addressing	38
6.1.5 Data types	39
6.2 ASEs	46
6.2.1 Object management ASE.....	46
6.2.2 Connection manager ASE.....	154
6.2.3 Connection ASE	172
6.3 ARs	186
6.3.1 Overview	186
6.3.2 UCMM AR formal model	197
6.3.3 Transport AR formal model.....	199
6.3.4 AR ASE services	209
6.4 Summary of FAL classes	217

6.5 Permitted FAL services by AR type	218
Bibliography.....	220
Figure 1 – Overview of ASEs and object classes	38
Figure 2 – Addressing format using MAC, class, instance and attribute IDs	39
Figure 3 – Identity object state transition diagram	60
Figure 4 – Explicit and Implicit Setting interaction	63
Figure 5 – Static Assembly state transition diagram	67
Figure 6 – Dynamic Assembly state transition diagram	68
Figure 7 – Typical timing relationships for acknowledged data production.....	79
Figure 8 – Example of a COS system with two acking devices	80
Figure 9 – Message flow in COS connection – one Connection object, one consumer.....	80
Figure 10 – Message flow in COS connection – multiple consumers	81
Figure 11 – Path Reconfiguration in a ring topology.....	93
Figure 12 – CPF2 time synchronization offset clock model.....	94
Figure 13 – CPF2 time synchronization system with offset clock model	95
Figure 14 – CPF2 time synchronization group startup sequence	97
Figure 15 – Parameter object state transition diagram	104
Figure 16 – Example of Find_Next_Object_Instance service	130
Figure 17 – Transmission Trigger Timer behavior	180
Figure 18 – Inactivity watchdog timer	181
Figure 19 – Using tools for configuration.....	181
Figure 20 – Production Inhibit Timer behavior.....	182
Figure 21 – Context of transport services within the connection model.....	189
Figure 22 – Application-to-application view of data transfer	189
Figure 23 – Data flow diagram for a link producer	190
Figure 24 – Data flow diagram for a link consumer.....	191
Figure 25 – Triggers	192
Figure 26 – Binding transport instances to the producer and consumer of a transport connection that does not have a reverse data path	193
Figure 27 – Binding transport instances to the producers and consumers of a transport connection that does have a reverse data path	193
Figure 28 – Binding transport instances to the producer and consumers of a multipoint connection when the transport connection does not have a reverse data path	194
Figure 29 – Binding transport instances to the producers and consumers of a multipoint connection when the transport connection does have reverse data paths	194
Table 1 – Valid IANA MIB printer codes for character set selection	35
Table 2 – Common elements	41
Table 3 – ST language elements.....	42
Table 4 – Type conversion operations.....	43
Table 5 – Values of implementation-dependent parameters	45
Table 6 – Extensions to IEC 61131-3:2003	45
Table 7 – Identity object state event matrix.....	61

Table 8 – Static Assembly state event matrix	67
Table 9 – Static Assembly instance attribute access	68
Table 10 – Dynamic Assembly state event matrix	69
Table 11 – Dynamic Assembly instance attribute access.....	69
Table 12 – Message Router object Forward_Open parameters	72
Table 13 – Acknowledge Handler object state event matrix.....	76
Table 14 – Producing I/O application object state event matrix	77
Table 15 – PTPEnable attribute default values.....	84
Table 16 – Profile identification.....	90
Table 17 – Profile default settings and ranges	91
Table 18 – Profile transports.....	91
Table 19 – Default PTP clock settings.....	92
Table 20 – Hand_Set clock quality management.....	92
Table 21 – Path Reconfiguration Signalling message.....	93
Table 22 – Parameter object state event matrix	104
Table 23 – Status codes	107
Table 24 – Get_Attributes_All service parameters.....	109
Table 25 – Set_Attributes_All service parameters	111
Table 26 – Get_Attribute_List service parameters	113
Table 27 – Set_Attribute_List service parameters	115
Table 28 – Reset service parameters.....	117
Table 29 – Start service parameters	119
Table 30 – Stop service parameters.....	120
Table 31 – Create service parameters	122
Table 32 – Delete service parameters.....	124
Table 33 – Get_Attribute_Single service parameters.....	125
Table 34 – Set_Attribute_Single service parameters	127
Table 35 – Find_Next_Object_Instance service parameters	129
Table 36 – NOP service parameters	131
Table 37 – Apply_Attributes service parameters	132
Table 38 – Save service parameters	134
Table 39 – Restore service parameters.....	135
Table 40 – Get_Member service parameters.....	137
Table 41 – Set_Member service parameters	139
Table 42 – Insert_Member service parameters.....	141
Table 43 – Remove_Member service parameters.....	143
Table 44 – Group_Sync service parameters.....	144
Table 45 – Add_AckData_Path service parameters.....	146
Table 46 – Remove_AckData_Path service parameters	147
Table 47 – Get_Enum_String service parameters	148
Table 48 – Symbolic_Translation service parameters.....	150
Table 49 – Flash_LEDs service parameters	151
Table 50 – Multiple_Service_Packet service parameters.....	153

Table 51 – CM_Open service parameters 163

Table 52 – CM_Close service parameters 165

Table 53 – CM_Unconnected_Send service parameters 167

Table 54 – CM_Get_Connection_Data service parameters 168

Table 55 – CM_Search_Connection_Data service parameters 170

Table 56 – CM_Get_Connection_Data service parameters 171

Table 57 – I/O Connection object attribute access 176

Table 58 – Bridged Connection object attribute access 177

Table 59 – Explicit messaging object attribute access 178

Table 60 – Connection_Bind service parameters 184

Table 61 – Service_Name service parameters 185

Table 62 – How production trigger, transport class, and CM_RPI determine when data is produced 188

Table 63 – Transport classes 199

Table 64 – UCMM_Create service parameters 210

Table 65 – UCMM_Delete service parameters 211

Table 66 – UCMM_Write service parameters 212

Table 67 – UCMM_Abort service parameters 213

Table 68 – TR_Write service parameters 214

Table 69 – TR_Trigger service parameters 215

Table 70 – TR_Packet_arrived service parameters 215

Table 71 – TR_Ack_received service parameters 216

Table 72 – TR_Verify service parameters 216

Table 73 – TR_Status_updated service parameters 217

Table 74 – FAL class summary 218

Table 75 – FAL services by AR type 219

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELD BUS SPECIFICATIONS –

Part 5-2: Application layer service definition – Type 2 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-5-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- addition of a data type in 5.3.2;
- clarifications of Object management ASE in 6.2.1;
- extensions of General ASE in 6.2.1.2.1;
- extensions/clarifications of Identity ASE in 6.2.1.2.2;
- update of Message Router ASE in 6.2.1.2.4;
- extensions/clarifications of Time Sync ASE in 6.2.1.2.6;
- updates of Parameter ASE in 6.2.1.2.7;
- updates of FAL ASE service specification in 6.2.1.3;
- extensions/clarifications of Connection manager ASE in 6.2.2;
- extensions/clarifications of Connection ASE in 6.2.3;
- extensions/clarifications of Application type in 6.3.1.4.5.
- miscellaneous editorial corrections.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-2: Application layer service definition – Type 2 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 2 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 2 fieldbus application layer in terms of:

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 2 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can