

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



---

**Industrial communication networks – Fieldbus specifications –  
Part 5-10: Application layer service definition – Type 10 elements**

**Reseaux de communication industriels – Specifications des bus de terrain –  
Partie 5-10: Définition des services de la couche application – Eléments de  
type 10**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC online collection - [oc.iec.ch](http://oc.iec.ch)

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

---

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC -

[webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC online collection - [oc.iec.ch](http://oc.iec.ch)

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



---

**Industrial communication networks – Fieldbus specifications –  
Part 5-10: Application layer service definition – Type 10 elements**

**Reseaux de communication industriels – Specifications des bus de terrain –  
Partie 5-10: Définition des services de la couche application – Éléments de  
type 10**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-1005-7

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

|   |    |
|---|----|
| FOREWORD.....   | 15 |
| INTRODUCTION.....   | 17 |
| 1 Scope.....  | 18 |
| 1.1 General.....  | 18 |
| 1.2 Specifications .....  | 19 |
| 1.3 Conformance .....   | 19 |
| 2 Normative references .....  | 19 |
| 3 Terms, definitions, abbreviations, symbols and conventions .....      | 22 |
| 3.1 Referenced terms and definitions.....                               | 22 |
| 3.1.1 ISO/IEC 7498-1 terms.....   | 22 |
| 3.1.2 ISO/IEC 8822 terms.....   | 22 |
| 3.1.3 ISO/IEC 9545 terms.....   | 22 |
| 3.1.4 ISO/IEC 8824-1 terms.....   | 23 |
| 3.2 Additional Type 10 terms and definitions.....                       | 23 |
| 3.3 Additional Type 10 terms and definitions for media redundancy ..... | 30 |
| 3.4 Abbreviations and symbols .....                                     | 32 |
| 3.4.1 General .....   | 32 |
| 3.4.2 Additional Type 10 abbreviations and symbols.....                 | 33 |
| 3.4.3 Abbreviations and symbols for services .....                      | 34 |
| 3.5 Conventions.....  | 34 |
| 3.5.1 Overview .....  | 34 |
| 3.5.2 General conventions.....  | 34 |
| 3.5.3 Conventions for class definitions .....                           | 34 |
| 3.5.4 Conventions for service definitions .....                         | 36 |
| 3.5.5 Conventions used in state machines.....                           | 37 |
| 4 Concepts .....  | 40 |
| 5 Data type ASE.....  | 40 |
| 5.1 General.....  | 40 |
| 5.1.1 Overview .....  | 40 |
| 5.1.2 Date and time type specifics.....                                 | 41 |
| 5.1.3 Transfer of user data .....                                       | 41 |
| 5.1.4 Data type overview .....  | 41 |
| 5.2 Formal definition of data type objects.....                         | 44 |
| 5.2.1 Data type class.....  | 44 |
| 5.3 FAL defined data types .....  | 45 |
| 5.3.1 Fixed length types .....  | 45 |
| 5.3.2 Variable Length types.....  | 66 |
| 5.4 Data type ASE service specification.....                            | 69 |
| 6 Communication model for common services .....                         | 69 |
| 6.1 Concepts .....  | 69 |
| 6.1.1 Overview .....  | 69 |
| 6.1.2 Middle Layer ASEs .....   | 69 |
| 6.2 ASE data types.....   | 69 |
| 6.3 Application Service Elements.....                                   | 69 |
| 6.3.1 Remote procedure call ASE.....                                    | 69 |
| 6.3.2 Domain name system ASE .....                                      | 78 |

|                       |  |     |
|-----------------------|--|-----|
| 6.3.3                 | Simple network management ASE .....                  | 79  |
| 6.3.4                 | IP suite ASE .....                                   | 80  |
| 6.3.5                 | Real time cyclic ASE .....                           | 84  |
| 6.3.6                 | Real time acyclic ASE.....                           | 100 |
| 6.3.7                 | Discovery and basic configuration ASE.....           | 110 |
| 6.3.8                 | Dynamic host configuration ASE.....                  | 138 |
| 6.3.9                 | IEEE 802.1AB ASE.....                                | 138 |
| 6.3.10                | Media redundancy ASE .....                           | 151 |
| 6.3.11                | Precision time control ASE .....                     | 158 |
| 6.3.12                | IEEE 802.1AS ASE.....                                | 172 |
| 6.3.13                | Virtual Bridges ASE .....                            | 175 |
| 6.3.14                | MAC Bridges ASE .....                                | 178 |
| 6.3.15                | Fragmentation ASE .....                              | 191 |
| 6.3.16                | IEEE 802.3 ASE .....                                 | 192 |
| 6.3.17                | Common DL mapping ASE .....                          | 195 |
| 7                     | Communication model for decentralized periphery..... | 200 |
| 7.1                   | Concepts .....                                       | 200 |
| 7.1.1                 | User requirements .....                              | 200 |
| 7.1.2                 | Features .....                                       | 200 |
| 7.1.3                 | Associations .....                                   | 201 |
| 7.1.4                 | Device types.....                                    | 202 |
| 7.1.5                 | Instance model and device addresses .....            | 210 |
| 7.1.6                 | Application process .....                            | 210 |
| 7.1.7                 | Application service element .....                    | 217 |
| 7.1.8                 | Application relationship.....                        | 219 |
| 7.2                   | ASE data types .....                                 | 220 |
| 7.3                   | ASEs .....   | 220 |
| 7.3.1                 | AR ASE .....   | 220 |
| 7.3.2                 | Real Identification ASE.....                         | 355 |
| 7.3.3                 | Communication Interface Management ASE .....         | 445 |
| 7.3.4                 | Diagnosis ASE.....                                   | 516 |
| 7.3.5                 | PE ASE .....   | 561 |
| 7.3.6                 | LogBook ASE .....                                    | 571 |
| 7.3.7                 | RS ASE .....   | 574 |
| 7.3.8                 | Time ASE .....                                       | 599 |
| 7.4                   | Application characteristics .....                    | 604 |
| 7.4.1                 | Device ident number.....                             | 604 |
| 7.4.2                 | Network topology.....                                | 604 |
| 7.5                   | Summary of FAL services .....                        | 606 |
| 7.5.1                 | IO device .....                                      | 606 |
| 7.5.2                 | IO controller .....                                  | 607 |
| 7.5.3                 | IO Supervisor .....                                  | 607 |
| Annex A (informative) | Device instances .....                               | 608 |
| Annex B (informative) | Components of an Ethernet interface .....            | 610 |
| Annex C (informative) | Scheme of MAC address assignment .....               | 614 |
| Annex D (informative) | Measurement of the fast startup time .....           | 615 |
| Annex E (informative) | Dynamic Frame Packing.....                           | 616 |
| Annex F (informative) | Precondition for Diagnosis.....                      | 624 |

|  |     |
|--|-----|
| Bibliography.....  | 629 |
| Figure 1 – Middle Layer ASEs communication architecture .....  | 69  |
| Figure 2 – Sequence Chart for reading the EndPointMapper.....  | 71  |
| Figure 3 – Media redundancy diagnosis dependencies .....   | 157 |
| Figure 4 – PTCP applications.....  | 158 |
| Figure 5 – Example of periods at a local port .....  | 177 |
| Figure 6 – Example of communication between controlling devices and field devices.....                               | 201 |
| Figure 7 – Example of communication between an engineering station and several<br>controlling and field devices..... | 202 |
| Figure 8 – Example of communication between field devices and a server station .....                                 | 202 |
| Figure 9 – Example of communication between field devices .....  | 202 |
| Figure 10 – Data Objects and Diagnosis Data Model .....  | 206 |
| Figure 11 – Example for channel modelling.....   | 207 |
| Figure 12 – Mapping to PROFINET device model .....   | 208 |
| Figure 13 – Identification hierarchy .....   | 208 |
| Figure 14 – Application Process with application process objects (APOs) .....  | 211 |
| Figure 15 – Access to a remote APO .....   | 212 |
| Figure 16 – Access to a remote APO for provider/consumer association.....  | 213 |
| Figure 17 – Overview of application processes .....  | 214 |
| Figure 18 – IO device with APs, slots and subslots .....   | 214 |
| Figure 19 – Example 1 structural units for interfaces and ports within API 0.....                                    | 216 |
| Figure 20 – Example 2 structural units for interfaces and ports within API 0.....                                    | 217 |
| Figure 21 – FAL ASEs communication architecture .....  | 218 |
| Figure 22 – Example of one AR with two AREPs.....  | 220 |
| Figure 23 – Example IO application relationship (one-to-one) .....   | 223 |
| Figure 24 – Example IO application relationship one-to-many .....  | 224 |
| Figure 25 – Implicit application relationship .....  | 225 |
| Figure 26 – State transition diagram DEVSM .....   | 257 |
| Figure 27 – State transition diagram CTLSM.....  | 265 |
| Figure 28 – Assignment of Communication Relationship to Application Relationship.....                                | 270 |
| Figure 29 – Overview Communication Relationship Class service interactions .....                                     | 273 |
| Figure 30 – Example for an intersection of IO device, slot, and AR .....   | 336 |
| Figure 31 – Substitute Value.....  | 364 |
| Figure 32 – State transition diagram RSMSM.....  | 372 |
| Figure 33 – Ownership handling.....  | 376 |
| Figure 34 – State transition diagram OWNSM.....  | 379 |
| Figure 35 – State transition diagram ASSSM .....   | 380 |
| Figure 36 – State transition diagram PLUGSM.....   | 392 |
| Figure 37 – State transition diagram PULLSM.....   | 395 |
| Figure 38 – Basic model for isochronous applications .....   | 424 |
| Figure 39 – General isochronous application model (example CACF == 1) .....  | 425 |
| Figure 40 – General isochronous application model (example CACF == 2) .....  | 426 |

|  |     |
|--|-----|
| Figure 41 – ASE relations in an IO device operating in isochronous mode for a submodule .....      | 432 |
| Figure 42 – State transition diagram of ISOM_SYNC .....  | 434 |
| Figure 43 – State transition diagram ISOM_OUT .....  | 437 |
| Figure 44 – State transition diagram ISOM_IN .....   | 442 |
| Figure 45 – State transition diagram SYNC_DIAG .....   | 484 |
| Figure 46 – MRP interconnection .....  | 506 |
| Figure 47 – Diagnosis Base Model .....   | 516 |
| Figure 48 – Severity classification of fault, maintenance and qualified .....                      | 517 |
| Figure 49 – Data Base Model .....  | 518 |
| Figure 50 – State transition diagram DIAG_DIAG .....   | 547 |
| Figure 51 – State transition diagram DIAG_MR .....   | 551 |
| Figure 52 – State transition diagram DIAG_MD .....   | 554 |
| Figure 53 – State transition diagram DIAG_QUALIFIED .....  | 558 |
| Figure 54 – Architecture .....   | 562 |
| Figure 55 – State transition diagram PESM .....  | 570 |
| Figure 56 – Reporting System components .....  | 575 |
| Figure 57 – AR / ARSet and Reporting System .....  | 576 |
| Figure 58 – Max Scan Delay .....   | 584 |
| Figure 59 – RS Incident window .....   | 587 |
| Figure 60 – State transition diagram RSOBS .....   | 592 |
| Figure 61 – State transition diagram RSBUF .....   | 596 |
| Figure 62 – State transition diagram TimeSM .....  | 602 |
| Figure 63 – Example of network topology including slower wireless segments .....                   | 605 |
| Figure 64 – Example of media redundancy including wireless segments .....                          | 605 |
| Figure A.1 – Instance model .....  | 608 |
| Figure B.1 – Scheme of an Ethernet interface .....   | 610 |
| Figure B.2 – Scheme of an Ethernet interface with bridging ability .....                           | 611 |
| Figure B.3 – Scheme of an Ethernet interface with optical ports .....                              | 612 |
| Figure B.4 – Scheme of an Ethernet interface with bridging ability using radio communication ..... | 613 |
| Figure B.5 – Scheme of an Ethernet interface with radio communication .....                        | 613 |
| Figure C.1 – Scheme of MAC address assignment .....  | 614 |
| Figure D.1 – Measurement of the fast startup time .....  | 615 |
| Figure E.1 – Frame Layout .....  | 616 |
| Figure E.2 – Subframe Layout .....   | 617 |
| Figure E.3 – End to End .....  | 618 |
| Figure E.4 – Dynamic frame packing .....   | 618 |
| Figure E.5 – Dynamic frame packing – Truncation of outputs .....                                   | 619 |
| Figure E.6 – Dynamic frame packing – Outbound Pack .....   | 619 |
| Figure E.7 – Dynamic frame packing – Concatenation of inputs .....                                 | 620 |
| Figure E.8 – Dynamic frame packing – Inbound Pack .....  | 621 |
| Figure E.9 – Dynamic frame packing – Distributed watchdog .....                                    | 623 |
| Figure E.10 – Interrelation between IO CR and dynamically packed frame .....                       | 623 |

|   |    |
|---|----|
| Table 1 – State machine description elements .....              | 37 |
| Table 2 – Description of state machine elements .....           | 38 |
| Table 3 – Conventions used in state machines .....              | 38 |
| Table 4 – Conventions for services used in state machines ..... | 39 |
| Table 5 – Data type overview.....                               | 41 |
| Table 6 – V2 octets.....  | 46 |
| Table 7 – L2 octets .....                                       | 46 |
| Table 8 – E2 octets.....  | 47 |
| Table 9 – E2 value range.....                                   | 47 |
| Table 10 – Unipolar2.16 octets .....                            | 48 |
| Table 11 – Unipolar2.16 value range .....                       | 48 |
| Table 12 – N2 value range.....                                  | 49 |
| Table 13 – N4 value range.....                                  | 50 |
| Table 14 – X2 value range.....                                  | 51 |
| Table 15 – X4 value range.....                                  | 52 |
| Table 16 – C4 value range.....                                  | 53 |
| Table 17 – T2 value range .....                                 | 54 |
| Table 18 – T4 value range .....                                 | 55 |
| Table 19 – D2 value range.....                                  | 56 |
| Table 20 – R2 value range.....                                  | 56 |
| Table 21 – Status value range .....                             | 57 |
| Table 22 – Status value range .....                             | 58 |
| Table 23 – F message trailer with 4 octets.....                 | 62 |
| Table 24 – Unsigned16_S octets .....                            | 64 |
| Table 25 – Unsigned16_S meaning.....                            | 64 |
| Table 26 – Integer16_S octets .....                             | 65 |
| Table 27 – Integer16_S meaning .....                            | 65 |
| Table 28 – Unsigned8_S octets .....                             | 65 |
| Table 29 – Unsigned8_S meaning .....                            | 65 |
| Table 30 – OctetString_S octets .....                           | 66 |
| Table 31 – OctetString_S status bits.....                       | 67 |
| Table 32 – Connect.....   | 72 |
| Table 33 – Release.....   | 73 |
| Table 34 – Read .....   | 74 |
| Table 35 – Write .....  | 75 |
| Table 36 – Control .....  | 76 |
| Table 37 – ReadImplicit .....                                   | 77 |
| Table 38 – Add Static ARP Cache Entry .....                     | 83 |
| Table 39 – Remove Static ARP Cache Entry.....                   | 83 |
| Table 40 – PPM Set Prov Data .....                              | 89 |
| Table 41 – PPM Set Prov Status.....                             | 90 |
| Table 42 – PPM Activate.....                                    | 91 |

|   |     |
|---|-----|
| Table 43 – PPM Close .....  | 93  |
| Table 44 – PPM Start.....   | 94  |
| Table 45 – PPM Error .....  | 94  |
| Table 46 – Get Cons Data .....                                      | 94  |
| Table 47 – CPM Get cons status.....                                 | 95  |
| Table 48 – CPM Set RedRole .....                                    | 96  |
| Table 49 – CPM Activate .....                                       | 97  |
| Table 50 – CPM NoData .....   | 99  |
| Table 51 – CPM Stop.....  | 99  |
| Table 52 – CPM New Data Indication.....                             | 100 |
| Table 53 – APMS Activate .....                                      | 103 |
| Table 54 – APMR Activate .....                                      | 104 |
| Table 55 – APMS A Data .....  | 106 |
| Table 56 – APMR A Data .....  | 107 |
| Table 57 – APMR Ack.....  | 107 |
| Table 58 – APMS Error.....  | 108 |
| Table 59 – APMS Error ERRCLS/ERRCODE .....                          | 108 |
| Table 60 – APMR Error.....  | 109 |
| Table 61 – APMR Error ERRCLS/ERRCODE.....                           | 109 |
| Table 62 – APMS_Close.....  | 109 |
| Table 63 – APMR_Close.....  | 110 |
| Table 64 – Get.....   | 118 |
| Table 65 – Set.....   | 123 |
| Table 66 – Local Set Command .....                                  | 128 |
| Table 67 – Identify.....  | 130 |
| Table 68 – Hello .....  | 136 |
| Table 69 – System capabilities .....                                | 144 |
| Table 70 – Auto negotiation support and status .....                | 145 |
| Table 71 – MDI Power Support.....                                   | 146 |
| Table 72 – Link aggregation status .....                            | 146 |
| Table 73 – Remote systems data change.....                          | 150 |
| Table 74 – Start bridge .....                                       | 165 |
| Table 75 – Start slave.....   | 166 |
| Table 76 – Start master .....                                       | 167 |
| Table 77 – Stop bridge.....   | 168 |
| Table 78 – Stop slave .....   | 169 |
| Table 79 – Stop master.....   | 170 |
| Table 80 – Sync state change.....                                   | 170 |
| Table 81 – Line Delay change.....                                   | 171 |
| Table 82 – Local Get Time.....                                      | 174 |
| Table 83 – Local time state info .....                              | 174 |
| Table 84 – Allowed values of Forwarding Mode .....                  | 181 |
| Table 85 – Allowed values of Fast Forwarding Multicast MAC Add..... | 181 |

|  |     |
|--|-----|
| Table 86 – Tx Port Entry .....   | 184 |
| Table 87 – Dependencies of RedPeriodBegin and GreenPeriodBegin .....     | 187 |
| Table 88 – Port state change .....                                       | 190 |
| Table 89 – Set port state .....  | 190 |
| Table 90 – Flush filtering data base .....                               | 191 |
| Table 91 – MAU Type change .....   | 194 |
| Table 92 – Set MAU Type .....  | 194 |
| Table 93 – P Data .....  | 195 |
| Table 94 – N Data .....  | 197 |
| Table 95 – A Data .....  | 198 |
| Table 96 – C Data .....  | 199 |
| Table 97 – Requirements and features .....                               | 200 |
| Table 98 – Binding application relationship services .....               | 226 |
| Table 99 – Device Access .....   | 229 |
| Table 100 – Companion AR .....   | 229 |
| Table 101 – Acknowledge Companion AR .....                               | 230 |
| Table 102 – Startup Mode .....   | 230 |
| Table 103 – Pull Module Alarm Allowed .....                              | 230 |
| Table 104 – Input Valid on Backup AR .....                               | 233 |
| Table 105 – Mode .....   | 234 |
| Table 106 – APStructureIdentifier with API := 0 .....                    | 234 |
| Table 107 – APStructureIdentifier with API != 0 .....                    | 235 |
| Table 108 – RS Alarm Transport Mode .....                                | 235 |
| Table 109 – Connect .....  | 237 |
| Table 110 – Connect Device Access .....                                  | 243 |
| Table 111 – Release .....  | 244 |
| Table 112 – Prm Begin .....  | 246 |
| Table 113 – Prm End .....  | 248 |
| Table 114 – Application Ready .....                                      | 249 |
| Table 115 – Abort .....  | 250 |
| Table 116 – Local AR Abort .....   | 251 |
| Table 117 – Local Set AR State .....                                     | 251 |
| Table 118 – Local AR In Data .....                                       | 251 |
| Table 119 – Data elements of Read AR Data .....                          | 252 |
| Table 120 – Data elements of Expected Fast Startup Data .....            | 254 |
| Table 121 – Remote primitives issued or received by DEVSM .....          | 255 |
| Table 122 – Local primitives issued or received by DEVSM .....           | 256 |
| Table 123 – State table DEVSM .....                                      | 258 |
| Table 124 – Functions, Macros, Timers and Variables by DEVSM .....       | 263 |
| Table 125 – Remote primitives issued or received by CTLISM .....         | 264 |
| Table 126 – Local primitives issued or received by CTLISM .....          | 264 |
| Table 127 – State table CTLISM .....                                     | 266 |
| Table 128 – Functions, Macros, Timers and Variables used by CTLISM ..... | 268 |

|  |     |
|--|-----|
| Table 129 – Binding communication relationship services .....                        | 274 |
| Table 130 – Traffic Classes versus RT Class .....                                    | 276 |
| Table 131 – Local Set Input .....  | 284 |
| Table 132 – Local Set Input IOCS .....   | 285 |
| Table 133 – Local Get Input .....  | 286 |
| Table 134 – Local Get Input IOCS .....   | 287 |
| Table 135 – Local New Input .....  | 288 |
| Table 136 – Local Set Output .....   | 289 |
| Table 137 – Local Set Output IOCS .....  | 290 |
| Table 138 – Local Get Output .....   | 291 |
| Table 139 – Local Get Output IOCS .....  | 292 |
| Table 140 – Local New Output .....   | 293 |
| Table 141 – Local Set Provider State .....   | 294 |
| Table 142 – Local Set Redundancy .....   | 295 |
| Table 143 – Local Set State .....  | 295 |
| Table 144 – Local Data State Changed .....   | 296 |
| Table 145 – Binding expected identification services .....                           | 303 |
| Table 146 – Module State .....   | 305 |
| Table 147 – AR Info .....  | 308 |
| Table 148 – Ident Info .....   | 309 |
| Table 149 – General Data definition for identification services .....                | 309 |
| Table 150 – Data elements of Read Module Diff Block .....                            | 311 |
| Table 151 – Alarm type .....   | 315 |
| Table 152 – Alarm types attached to diagnosis ASE .....                              | 317 |
| Table 153 – Alarm types attached to ownership .....                                  | 317 |
| Table 154 – Alarm types attached to common profiles, profiles, and application ..... | 318 |
| Table 155 – Binding Alarm services .....   | 318 |
| Table 156 – Alarm Notification .....   | 322 |
| Table 157 – Channel Diagnosis .....  | 324 |
| Table 158 – Manufacturer Specific Diagnosis .....                                    | 324 |
| Table 159 – Submodule Diagnosis State .....  | 325 |
| Table 160 – AR Diagnosis State .....   | 325 |
| Table 161 – User Structure Identifier .....  | 326 |
| Table 162 – Semantics of Specifier .....   | 328 |
| Table 163 – Binding Record Data services .....                                       | 336 |
| Table 164 – Read .....   | 338 |
| Table 165 – Read Services .....  | 340 |
| Table 166 – Read Implicit .....  | 342 |
| Table 167 – Read Query .....   | 343 |
| Table 168 – Write .....  | 344 |
| Table 169 – Write Services .....   | 345 |
| Table 170 – Data elements of Write Combined Object Container .....                   | 346 |
| Table 171 – Local Write Multiple .....   | 347 |

|   |     |
|---|-----|
| Table 172 – Local New Write Multiple .....                                | 350 |
| Table 173 – Binding real identification services.....                     | 356 |
| Table 174 – Local Add Submodule.....                                      | 359 |
| Table 175 – Local Remove Submodule .....                                  | 360 |
| Table 176 – Local Update Submodule.....                                   | 360 |
| Table 177 – Data elements of Read API Data .....                          | 362 |
| Table 178 – Data elements of Read Record Input Data Object Element .....  | 363 |
| Table 179 – Data elements of Read Record Output Data Object Element ..... | 366 |
| Table 180 – Data elements of Read Substitute Value.....                   | 367 |
| Table 181 – Selector for Read GSD Data.....                               | 369 |
| Table 182 – Data elements of Read GSD Data .....                          | 369 |
| Table 183 – Remote primitives issued or received by RSMSM .....           | 371 |
| Table 184 – Local primitives issued or received by RSMSM.....             | 371 |
| Table 185 – State table RSMSM .....                                       | 372 |
| Table 186 – Functions, Macros, Timers and Variables used by RSMSM .....   | 374 |
| Table 187 – Rules for Submodule State.Ident Info .....                    | 374 |
| Table 188 – Remote primitives issued or received by OWNSM and ASSSM.....  | 378 |
| Table 189 – Local primitives issued or received by OWNSM .....            | 379 |
| Table 190 – State table OWNSM .....                                       | 380 |
| Table 191 – State table ASSSM.....  | 387 |
| Table 192 – Functions, Macros, Timers and Variables used by OWNSM.....    | 388 |
| Table 193 – Functions, Macros, Timers and Variables used by ASSSM .....   | 389 |
| Table 194 – Rules for Submodule State.AR Info .....                       | 389 |
| Table 195 – Remote primitives issued or received by PLUGSM .....          | 390 |
| Table 196 – Local primitives issued or received by PLUGSM .....           | 391 |
| Table 197 – State table PLUGSM .....                                      | 393 |
| Table 198 – Functions, Macros, Timers and Variables used by PLUGSM.....   | 394 |
| Table 199 – Remote primitives issued or received by PULLSM .....          | 395 |
| Table 200 – Local primitives issued or received by PULLSM.....            | 395 |
| Table 201 – State table PULLSM .....                                      | 396 |
| Table 202 – Functions, Macros, Timers and Variables used by PULLSM .....  | 397 |
| Table 203 – Binding I&M data services .....                               | 399 |
| Table 204 – Data elements of Read I&M0 Filter Data.....                   | 412 |
| Table 205 – Data elements of Read I&M0 Data.....                          | 415 |
| Table 206 – Data elements of Write I&M1 Data.....                         | 416 |
| Table 207 – Data elements of Write I&M2 Data.....                         | 417 |
| Table 208 – Data elements of Write I&M3 Data.....                         | 418 |
| Table 209 – Data elements of Write I&M4 Data.....                         | 418 |
| Table 210 – Data elements of Read I&M5 Data.....                          | 419 |
| Table 211 – Data elements of Read Asset Management Data .....             | 422 |
| Table 212 – Binding Isochronous Mode Application services.....            | 426 |
| Table 213 – Data elements of Write Isochronous Mode Data .....            | 431 |
| Table 214 – Remote primitives issued or received by ISOM_SYNC.....        | 433 |

|   |     |
|---|-----|
| Table 215 – Local primitives issued or received by ISOM_SYNC .....              | 433 |
| Table 216 – State table ISOM_SYNC .....   | 434 |
| Table 217 – Functions, Macros, Timers and Variables used by the ISOM_SYNC ..... | 435 |
| Table 218 – Remote primitives issued or received for ISOM_OUT .....             | 435 |
| Table 219 – Local primitives issued or received for ISOM_OUT .....              | 436 |
| Table 220 – State table ISOM_OUT .....  | 438 |
| Table 221 – Functions, Macros, Timers and Variables used by the ISOM_OUT .....  | 440 |
| Table 222 – Remote primitives issued or received for ISOM_IN .....              | 441 |
| Table 223 – Local primitives issued or received for ISOM_IN .....               | 441 |
| Table 224 – State table ISOM_IN .....   | 443 |
| Table 225 – Functions, Macros, Timers and Variables used by the ISOM_IN .....   | 444 |
| Table 226 – Binding Communication Interface Management services .....           | 446 |
| Table 227 – Subslot number for interface submodules .....                       | 449 |
| Table 228 – Subslot number for port submodules .....                            | 453 |
| Table 229 – Data elements of Read PDev Data .....                               | 458 |
| Table 230 – Data elements of Read PD Real Data .....                            | 458 |
| Table 231 – Data elements of Read PD Expected Data .....                        | 460 |
| Table 232 – Data elements of Read PD Interface Data Real .....                  | 461 |
| Table 233 – Data elements of Write PD Interface Adjust .....                    | 462 |
| Table 234 – Data elements of Write PD Interface FSU Data Adjust .....           | 463 |
| Table 235 – Data elements of Write PD NC Data Check .....                       | 464 |
| Table 236 – Data elements of Read PD Port Data Real .....                       | 465 |
| Table 237 – Data elements of Read PD Port Data Real Extended .....              | 466 |
| Table 238 – Data elements of Write PD Port Data Check .....                     | 467 |
| Table 239 – Data elements of Write PD Port Data Adjust .....                    | 469 |
| Table 240 – Data elements of Read Port FO Data Real .....                       | 470 |
| Table 241 – Data elements of Write PD Port FO Data Check .....                  | 471 |
| Table 242 – Data elements of Write PD Port FO Data Adjust .....                 | 471 |
| Table 243 – Data elements of Read PD Port Statistic .....                       | 472 |
| Table 244 – Binding PTCIP services .....  | 475 |
| Table 245 – Sync Properties Role .....  | 478 |
| Table 246 – Sync Class .....  | 478 |
| Table 247 – Data elements of Write PD Sync Data .....                           | 479 |
| Table 248 – Local Sync State Info .....   | 481 |
| Table 249 – Local SYNCH Event .....   | 482 |
| Table 250 – Remote primitives issued or received by SYNC_DIAG .....             | 483 |
| Table 251 – Local primitives issued or received by SYNC_DIAG .....              | 483 |
| Table 252 – State table SYNC_DIAG .....   | 485 |
| Table 253 – Functions, Macros, Timers and Variables used by SYNC_DIAG .....     | 486 |
| Table 254 – Binding MAC Bridge services .....                                   | 487 |
| Table 255 – Distributed Watchdog Factor .....                                   | 489 |
| Table 256 – Restart Factor For Distributed Watchdog .....                       | 489 |
| Table 257 – DFP Mode .....  | 490 |

|  |     |
|--|-----|
| Table 258 – SFIOCRProperties.DFPRedundantPathLayout.....   | 490 |
| Table 259 – SFCRC16 .....  | 490 |
| Table 260 – Data elements of Write PD IR Data .....  | 491 |
| Table 261 – Data elements of Write PD IR Subframe Data.....  | 493 |
| Table 262 – Binding Media Redundancy services .....  | 494 |
| Table 263 – Data elements of Read PD Interface MRP Data Real.....                                  | 496 |
| Table 264 – Data elements of Write PD Interface MRP Data Check .....                               | 498 |
| Table 265 – Data elements of Write PD Interface MRP Data Adjust .....                              | 499 |
| Table 266 – Data elements of Read PD Port MRP Data Real.....                                       | 501 |
| Table 267 – Data elements of Write PD Port MRP Data Adjust .....                                   | 501 |
| Table 268 – Data elements of Read PD Port MRPIC Data Real .....                                    | 502 |
| Table 269 – Data elements of Write PD Port MRPIC Data Check.....                                   | 503 |
| Table 270 – Data elements of Write PD Port MRPIC Data Adjust.....                                  | 503 |
| Table 271 – Binding IEEE 802.1AS services .....  | 507 |
| Table 272 – Data elements of Write PD Time Data .....  | 509 |
| Table 273 – List of supported MIBs.....  | 509 |
| Table 274 – Cross-referencing of MIB-II objects .....  | 510 |
| Table 275 – Cross-referencing of LLDP-MIB objects .....  | 510 |
| Table 276 – Cross-referencing of LLDP-EXT-PNIO MIB objects.....                                    | 510 |
| Table 277 – Cross-referencing of LLDP-EXT-DOT3 MIB objects .....                                   | 511 |
| Table 278 – Binding Autoconfiguration Data services.....   | 511 |
| Table 279 – Data elements of Read Autoconfiguration Data .....                                     | 514 |
| Table 280 – Binding Diagnosis services.....  | 521 |
| Table 281 – General Data definition for Diagnosis services.....                                    | 527 |
| Table 282 – Local Add Diagnosis Entry.....   | 530 |
| Table 283 – Local Remove Diagnosis Entry .....   | 531 |
| Table 284 – Local Update Diagnosis Entry.....  | 532 |
| Table 285 – Remote primitives issued or received by DIAG_DIAG .....                                | 547 |
| Table 286 – Local primitives issued or received by DIAG_DIAG .....                                 | 547 |
| Table 287 – State table DIAG_DIAG .....  | 548 |
| Table 288 – Functions, Macros, Timers and Variables used by DIAG_DIAG .....                        | 549 |
| Table 289 – Remote primitives issued or received by DIAG_MR .....                                  | 550 |
| Table 290 – Local primitives issued or received by DIAG_MR.....                                    | 551 |
| Table 291 – State table DIAG_MR .....  | 552 |
| Table 292 – Functions, Macros, Timers and Variables used by DIAG_MR.....                           | 552 |
| Table 293 – Remote primitives issued or received by DIAG_MD .....                                  | 554 |
| Table 294 – Local primitives issued or received by DIAG_MD.....                                    | 554 |
| Table 295 – State table DIAG_MD .....  | 555 |
| Table 296 – Functions, Macros, Timers and Variables used by the maintenance<br>demanded entry..... | 556 |
| Table 297 – Remote primitives issued or received by DIAG_QUALIFIED .....                           | 557 |
| Table 298 – Local primitives issued or received by DIAG_QUALIFIED .....                            | 557 |
| Table 299 – State table DIAG_QUALIFIED .....   | 559 |

|   |     |
|---|-----|
| Table 300 – Functions, Macros, Timers and Variables used by DIAG_QUALIFIED .....                      | 559 |
| Table 301 – Binding PE services .....   | 563 |
| Table 302 – Local Add PE Entity .....   | 564 |
| Table 303 – Local Remove PE Entity .....  | 565 |
| Table 304 – Local Update PE_OperationalMode .....   | 566 |
| Table 305 – PE Entity Filter Data definition .....  | 567 |
| Table 306 – PE Entity Filter Data definition .....  | 568 |
| Table 307 – Remote primitives issued or received by PESM .....  | 570 |
| Table 308 – Local primitives issued or received by PESM .....   | 570 |
| Table 309 – State table PESM .....  | 571 |
| Table 310 – Functions, Macros, Timers and Variables used by PESM .....                                | 571 |
| Table 311 – Binding LogBook services .....  | 572 |
| Table 312 – Data elements of Read LogBook Data .....  | 573 |
| Table 313 – Local Create LogBook Entry .....  | 574 |
| Table 314 – Binding RS services .....   | 581 |
| Table 315 – Immanent observers .....  | 583 |
| Table 316 – Configured observers .....  | 583 |
| Table 317 – Data elements of Local Add RS Event .....   | 589 |
| Table 318 – Data elements of RS Get Event .....   | 590 |
| Table 319 – Data elements of RS Ack Event .....   | 590 |
| Table 320 – Data elements of RS Adjust Observer .....   | 591 |
| Table 321 – Local primitives issued or received by RSOBS .....  | 592 |
| Table 322 – State table RSOBS .....   | 594 |
| Table 323 – Functions, Macros, Timers and Variables used by RSOBS .....                               | 595 |
| Table 324 – Local primitives issued or received by RSBUF .....  | 596 |
| Table 325 – State table RSBUF .....   | 597 |
| Table 326 – Functions, Macros, Timers and Variables used by RSBUF .....                               | 599 |
| Table 327 – Binding Time services .....   | 600 |
| Table 328 – Local Get Time .....  | 601 |
| Table 329 – Local primitives issued or received by TimeSM .....                                       | 602 |
| Table 330 – State table TimeSM .....  | 603 |
| Table 331 – Functions, Macros, Timers and Variables used by TimeSM .....                              | 604 |
| Table 332 – FAL services of the IO device .....   | 606 |
| Table 333 – FAL services of the IO controller .....   | 607 |
| Table F.1 – ChannelErrorType .....  | 624 |
| Table F.2 – Preconditions ChannelErrorType 0 – 0xFF .....   | 625 |
| Table F.3 – Preconditions for ChannelErrorType 0x0100 – 0x7FFF, 0x9000 – 0x9FFF .....                 | 625 |
| Table F.4 – Preconditions for ChannelErrorType “Data transmission impossible” .....                   | 625 |
| Table F.5 – Preconditions for ChannelErrorType “Remote mismatch” .....                                | 626 |
| Table F.6 – Preconditions for ChannelErrorType “Media redundancy mismatch – ring” .....               | 626 |
| Table F.7 – Preconditions for ChannelErrorType “Media redundancy mismatch -<br>interconnection” ..... | 627 |
| Table F.8 – Preconditions for ChannelErrorType “Sync mismatch” .....                                  | 627 |

|  |     |
|--|-----|
| Table F.9 – Preconditions for ChannelErrorType “Isochronous mode mismatch” .....                           | 627 |
| Table F.10 – Preconditions for ChannelErrorType “Multicast CR mismatch” .....                              | 627 |
| Table F.11 – Preconditions for ChannelErrorType “Fiber optic mismatch” .....                               | 628 |
| Table F.12 – Preconditions for ChannelErrorType “Network component function mismatch” .....                | 628 |
| Table F.13 – Preconditions for ChannelErrorType “Dynamic Frame Packing function mismatch” .....            | 628 |
| Table F.14 – Preconditions for ChannelErrorType “Media redundancy with planned duplication mismatch” ..... | 628 |
| Table F.15 – Preconditions for ChannelErrorType “Multiple interface mismatch” .....                        | 628 |

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –  
FIELDBUS SPECIFICATIONS –****Part 5-10: Application layer service definition –  
Type 10 elements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This International Standard IEC 61158-5-10 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- integration of system redundancy basic functionality;
- integration of dynamic reconfiguration basic functionality;
- integration of reporting system basic functionality;

- integration of asset management basic functionality;
- integration of media redundancy ring interconnection basic functionality.

The text of this International Standard is based on the following documents:

|              |                  |
|--------------|------------------|
| FDIS         | Report on voting |
| 65C/947/FDIS | 65C/950/RVD      |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

## **INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –**

### **Part 5-10: Application layer service definition – Type 10 elements**

#### **1 Scope**

##### **1.1 General**

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 10 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 10 fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 10 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can