

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



**High-voltage switchgear and controlgear –  
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for  
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable-terminations**

**Appareillage à haute tension –  
Partie 209: Raccordement de câbles pour appareillage sous enveloppe  
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles  
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou  
remplie d'un fluide**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

---

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



---

**High-voltage switchgear and controlgear –  
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for  
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable-terminations**

**Appareillage à haute tension –  
Partie 209: Raccordement de câbles pour appareillage sous enveloppe  
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles  
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou  
remplie d'un fluide**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.130.10

ISBN 978-2-8322-1098-1

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**



# REDLINE VERSION

## VERSION REDLINE



**High-voltage switchgear and controlgear –  
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for  
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable-terminations**

**Appareillage à haute tension –  
Partie 209: Raccordement de câbles pour appareillage sous enveloppe  
métallique à isolation gazeuse de tension assignée supérieure à 52 kV – Câbles  
remplis d'un fluide ou à isolation extrudée – Extrémité de câble de type sec ou  
remplie d'un fluide**

## CONTENTS

FOREWORD	4
INTRODUCTION TO Amendment 1	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Normal and special service conditions	9
4.1 General	9
4.2 Normal service conditions	9
4.3 Special service conditions	9
5 Ratings	9
5.1 General	9
5.2 Rated voltage of the equipment of the cable connection ( $U_{rm}$ )	10
5.3 Rated insulation level ( $U_d$ , $U_p$ , $U_s$ )	10
5.4 Rated frequency ( $f_r$ )	10
5.5 Rated continuous current ( $I_r$ )	10
5.6 Rated short-time withstand current ( $I_k$ )	10
5.7 Rated peak withstand current ( $I_p$ )	10
5.8 Rated duration of short circuit ( $t_k$ )	10
6 Design and construction	11
6.1 Gas and vacuum tightness	11
6.101 Limits of supply	11
6.101.1 General	11
6.101.2 Over-voltage protection and earthing	11
6.102 Filling pressure of insulating gas in the cable connection enclosure	12
6.103 Pressure withstand requirements	12
6.104 Mechanical forces on cable terminations	13
6.105 Switchgear connection interface and cable termination connection interface	13
7 Type tests	13
7.1 General	13
7.2 Electrical type tests of cable terminations	13
7.2.1 General	13
7.2.2 Electrical type test of cable terminations in a single-phase enclosure	14
7.2.3 Electrical type test of cable termination in a three-phase enclosure	14
7.2.4 Additional electrical type tests on the insulator to be installed by switchgear manufacturer (plug in cable termination)	14
7.3 Pressure test on the insulator of a cable termination	15
7.4 Leak rate type test on the insulator of a cable termination	15
8 Routine tests	16
8.1 General	16
8.2 Pressure test	16
8.3 Visual inspection	16
9 Standard dimensions	16
9.1 General	16
9.2 Fluid-filled cable terminations	16
9.3 Dry-type cable terminations	16

9.4	Three-phase cable connection enclosure .....	17
10	Information to be given with enquiries, tenders and orders .....	17
11	Rules for transport, storage, erection, service and maintenance .....	17
11.1	General.....	17
11.2	Tests after cable system installation .....	17
12	Safety practices and constraints during installation of cable connection to switchgear .....	18
13	Influence of the product on the environment .....	18
Annex A (informative) Mechanical forces applied on the flange of the cable connection enclosure.....		24
A.1	General.....	24
A.2	Recommendation when connecting cable systems to switchgear .....	24
Bibliography.....		26
Figure 1 – Operating pressure of the <del>SF<sub>6</sub></del> gas insulation in the cable connection enclosure.....		12
Figure 2 – Fluid-filled cable connection assembly – Typical arrangement.....		20
Figure 3 – Fluid-filled cable connection – Assembly dimensions .....		21
Figure 4 – Dry-type cable connection assembly – Typical arrangement.....		22
Figure 5 – Dry-type cable connection assembly – Assembly dimensions .....		23
Table 1 – Test voltages for additional electrical type tests according to 7.2.4.....		15
Table A.1 – Moment and forces applied on the flange of the cable connection enclosure attached to the cable termination during normal operation .....		25

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

#### **Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations**

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.**

**IEC 62271-209 edition 2.1 contains the second edition (2019-02) [documents 17C/696/FDIS and 17C/701/RVD] and its amendment 1 (2022-03) [documents 17C/833/FDIS and 17C/841/RVD].**

**In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.**

International Standard IEC 62271-209 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) New numbering in accordance with ISO/IEC directives, Part 2 (2016) and to IEC 62271-1:2017;
- b) Clause 3: addition of a definition for plug-in cable termination, filling pressure and minimum function pressure for insulation;
- c) Clause 7: An additional dielectric type test for plug-in cable termination was added; also a pressure type test as well as a leak rate test on the insulator of a cable termination was implemented;
- d) Clause 12: New clause about safety practices;
- e) Clause 13: New clause about influence of the product on the environment;
- f) New informative Annex A: Mechanical forces applied on the flange of the cable connection enclosure.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified in this standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION TO Amendment 1

This amendment includes the following modifications:

- a) In accordance with the decision taken at IEC Plenary Meeting October 2019 in Shanghai (17C/Shanghai/Sec07) Subclause 6.103, Figure 1 and Figure 2 have been modified;
- b) The CDV was modified in accordance with the above-mentioned documents and based on the decision taken at the virtual IEC Plenary Meeting in October 2021 (17C/823/RM).

NOTE CIGRE has published TB 784 "Standard design of a common, dry type plug-in interface for GIS and power cables up to 145 kV describing the basis for further standardisation of such a common interface. The matter will be dealt with during the next revision of IEC 62271-209.

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### **Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations**

#### **1 Scope**

This part of IEC 62271 covers the connection assembly of fluid-filled and extruded cables to gas-insulated metal enclosed switchgear (GIS), in single- or three-phase arrangements where the cable terminations are fluid-filled or dry-type and there is a separating insulating barrier between the cable insulation and the gas insulation of the switchgear.

The purpose of this document is to establish electrical and mechanical interchangeability between cable terminations and the gas-insulated metal-enclosed switchgear and to determine the limits of supply. It complements and amends, if applicable, the relevant IEC standards. For the purpose of this document the term "switchgear" is used for "gas-insulated metal enclosed switchgear".

It does not cover directly immersed cable terminations, as described in CIGRE brochure 89 [4]<sup>1</sup>.

#### **2 Normative references**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17:Tests – Test Q: Sealing*

IEC 60141 (all parts), *Tests on oil-filled and gas-pressure cables and their accessories*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF<sub>6</sub>) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480, *Guidelines for the checking and treatment of sulphur hexafluoride (SF<sub>6</sub>) taken from electrical equipment and specification for its re-use*

IEC 60840, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV (U<sub>m</sub> = 36 kV) up to 150 kV (U<sub>m</sub> = 170 kV) – Test methods and requirements*

IEC 62067, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV (U<sub>m</sub> = 170 kV) up to 500 kV (U<sub>m</sub> = 550 kV) – Test methods and requirements*

---

<sup>1</sup> Numbers in square brackets refer to the Bibliography.