

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above
52 kV**

**Appareillage à haute tension –
Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse et à
courant alternatif de tensions assignées supérieures à 52 kV**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above
52 kV**

**Appareillage à haute tension –
Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse et à
courant alternatif de tensions assignées supérieures à 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-3799-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Normal and special service conditions	10
5 Ratings	11
6 Design and construction	14
7 Type tests	27
8 Routine tests	41
9 Guide to the selection of switchgear and controlgear (informative)	44
10 Information to be given with enquiries, tenders and orders (informative)	44
11 Transport, storage, installation, operating instructions and maintenance	44
12 Safety	50
13 Influence of the product on the environment	51
Annex A (normative) Test procedure for dielectric test on three-phase encapsulated GIS, range II (above 245 kV)	52
Annex B (normative) Methods for testing gas-insulated metal-enclosed switchgear under conditions of arcing due to an internal fault	53
Annex C (informative) Technical and practical considerations of site testing	56
Annex D (informative) Calculation of pressure rise due to an internal fault	61
Annex E (informative) Information to be given with enquiries, tenders and orders	62
Annex F (informative) Service continuity	68
Annex G (informative) List of notes concerning certain countries	76
Bibliography	77
Figure 1 – Pressure coordination	19
Figure 2 – Example of arrangement of enclosures and gas compartments	24
Figure F.1 – MRE1X (e.g. repair of disconnector to busbar)	71
Figure F.2 – MRE00 (e.g. during visual inspection)	71
Figure F.3 – MRE01 (e.g. repair of circuit-breaker)	72
Figure F.4 – MRE11 (e.g. repair of disconnector)	72
Figure F.5 – MRE11 (e.g. extension of switchgear with a feeder bay)	73
Figure F.6 – MRE13 (e.g. repair of disconnector)	73
Figure F.7 – MRE2X (e.g. on-site dielectric test of busbar section A)	74
Figure F.8 – MRE2X (e.g. on-site dielectric test of busbar section 1)	74
Figure F.9 – MRE00 (e.g. repair of circuit-breaker)	75
Table 1 – Reference table of service conditions relevant to GIS	11
Table 2 – Rated insulation levels for rated voltages for equipment of range I (245 kV and below)	12
Table 3 – Rated insulation levels for rated voltages for equipment of range II (above 245 kV)	13

Table 4 – Performance criteria 20

Table 5 – Type tests 28

Table 6 – Test voltage for measuring PD intensity 31

Table 7 – On-site test voltages 48

Table A.1 – Switching impulse test conditions above 245 kV..... 52

Table E.1 – Normal and special service conditions 62

Table E.2 – Ratings 63

Table E.3 – Design and construction..... 64

Table E.4 – Bus ducts 65

Table E.5 – Bushing..... 65

Table E.6 – Cable connection 66

Table E.7 – Transformer connection 66

Table E.8 – Current transformer..... 66

Table E.9 – Inductive voltage transformer 66

Table E.10 – Documentation for enquiries and tenders 67

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-203 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the document has been aligned with IEC 62271-1:2017;
- b) beside SF₆ also alternative gases have been implemented where needed;
- c) the terms and definitions have been updated and terms not used have been removed;
- d) Subclause 6.16 “Gas and vacuum tightness” has been updated;

- e) Subclause 6.16.3 “Closed pressure systems”: Two classes of gas has been introduced:
- 1) $GWP \leq 1\,000$
 - 2) $GWP > 1\,000$
- and the tightness requirements for type tests for gasses with $GWP > 1\,000$ has been reduced from 0,5 % to 0,1 % per year per gas compartment;
- f) Subclause 6.108 “Interfaces”: Typical maximum pressures in service for interfaces connected to GIS have been defined;
- g) Subclauses 7.2 through 7.8 have been restructured;
- h) Subclause 7.107 “Corrosion test on earthing connections” has been updated;
- i) Subclause 7.108 “Corrosion tests on sealing systems of enclosures and auxiliary equipment” has been updated;
- j) Annex F ‘Service Continuity’ has been modified and aligned with the recommendations of CIGRE WG B3.51.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17C/835/FDIS	17C/844/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

1 Scope

This part of IEC 62271 specifies requirements for gas-insulated metal-enclosed switchgear in which the insulation is obtained, at least partly, by an insulating gas or gas mixture other than air at atmospheric pressure, for alternating current of rated voltages above 52 kV, for indoor and outdoor installation, and for service frequencies up to and including 60 Hz.

For the purpose of this document, the terms “GIS” and “switchgear” are used for “gas-insulated metal-enclosed switchgear”.

The gas-insulated metal-enclosed switchgear covered by this document consists of individual components intended to be directly connected together and able to operate only in this manner.

This document completes and amends, if applicable, the various relevant standards applying to the individual components constituting GIS.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-11, *Environmental testing – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-17, *Basic environmental testing procedures – Part 2-17: Tests – Test Q: Sealing*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-4:2014, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*

IEC 60137:2017, *Insulated bushings for alternating voltages above 1 000 V*

IEC 60141-1, *Tests on oil-filled and gas-pressure cables and their accessories – Part 1: Oil-filled, paper or polypropylene paper laminate insulated, metal-sheathed cables and accessories for alternating voltages up to and including 500 kV*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*