

**INSTITUTE OF
ENVIRONMENTAL
SCIENCES AND
TECHNOLOGY**

**Contamination Control Division
Technical Guide 1004**

IEST-G-CC1004

**Sequential-Sampling Plan for
Use in Classification of the
Particulate Cleanliness of Air in
Cleanrooms and Clean Zones**

INSTITUTE OF ENVIRONMENTAL SCIENCES AND TECHNOLOGY

Arlington Place One
2340 S. Arlington Heights Road, Suite 620
Arlington Heights, IL 60005-4510
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: iest@iest.org • Web: www.iest.org



This Guide is published by the INSTITUTE OF ENVIRONMENTAL SCIENCES AND TECHNOLOGY to advance contamination control technology and the technical and engineering sciences. Its use is entirely voluntary, and determination of its applicability and suitability for any particular use is solely the responsibility of the user.

Copyright © 1999 by the **INSTITUTE OF ENVIRONMENTAL SCIENCES AND TECHNOLOGY**

ISBN 978-1-877862-77-9

No part of this publication may be copied or reproduced in any form, or by any means, including electronic, mechanical, photocopying, or otherwise, without the prior written permission of the Institute of Environmental Sciences and Technology, 2340 S. Arlington Heights Road, Arlington Heights, IL 60005-4516.

INSTITUTE OF ENVIRONMENTAL SCIENCES AND TECHNOLOGY

Arlington Place One
2340 S. Arlington Heights Road, Suite 620
Arlington Heights, IL 60005-4510
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: iest@iest.org • Web: www.iest.org

Sequential-Sampling Plan for Use in Classification of the Particulate Cleanliness of Air in Cleanrooms and Clean Zones

IEST-G-CC1004

CONTENTS

SECTION

1	Application.....	5
2	Definitions	6
3	Background	6
4	Operating characteristic curve.....	6
5	Objectives	7
6	Sequential-sampling plan.....	8
7	References	11

APPENDIX

APPENDIX A; Multiple Evaluations	12
APPENDIX B; Cost Savings Example.....	13

FIGURE

Figure 1. Operating characteristic (OC) curve	7
Figure 2. Plot of sequential-sampling domains	8
Figure 3. Sequential-sampling count histories.....	9
Figure 4. Average sample duration vs. true mean count.....	10
Figure 5. Confidence intervals based on sample counts	10
Figure A1. Fractions accepted for samples of <21 counts	12

Sequential-Sampling Plan for Use in Classification of the Particulate Cleanliness of Air in Cleanrooms and Clean Zones

IEST-G-CC1004

[This guide is based on a paper by Cooper and Milholland (reference 7a).]

1 Application

This guide provides background and support for the use of sequential-sampling plans for the classification of air cleanliness in cleanrooms and clean zones. Such plans are generally most appropriate for environments where air cleanliness is expected to qualify as ISO Class 4 or cleaner.

The sequential-sampling plan described herein has been developed to match the operating characteristic (OC) curve of the traditional single-stage-sampling plan. As a result, the probability of passing or failing a given classification is about the same for both plans.

When compared to sampling times required by traditional single-stage-sampling methods, however, sequential sampling is found to be capable of saving about 80 percent of the sampling time when

the air sampled is very clean, 35 percent when the air just meets the class limit, and more than 80 percent when the concentration of particles in the air exceeds 2.5 times the class limit.

Sequential sampling is especially applicable as an alternative to a single-stage-sampling scheme in cases where the upper confidence limit (UCL) on the grand mean of the particle concentration is not required or when, with some further development, it can be used to provide an equivalent estimate of the UCL.

NOTE: The statistical validity of data from long-term sampling of very clean air at a given location is based upon the assumption that the particle concentration will remain relatively constant or will vary only in a random manner during the sampling period. Statistical validity may be degraded, however, if unique phenomena are present that can cause significant variations in concentration.